

Rescue Fire Protection District

BOARD OF DIRECTORS AGENDA

Special Meeting October 27, 2022

6:00 P.M.

5221 Deer Valley Road, Rescue, CA 95672

(P.O. Box 201)

(530) 677-1868

ATTENTION

Residents planning to address the Board of Directors at this Board meeting: due to the concerns about the COVID-19 virus, we respectfully ask if you are feeling ill for any reason not to attend in person.

Please submit your comments in writing to admin@rescuefiredepartment.org and they will be entered into the public record. If you are healthy and chose to attend the meeting, we ask that you wear a mask and maintain a six-foot buffer between you and others, as suggested by the State Department of Public Health.

Thank you for your understanding during these challenging times.

NOTE

If you need a disability-related modification or accommodation, including auxiliary aids or services, to participate in this meeting, please contact the Board Clerk at 916-933-6623; ext. 1038, at least two (2) days prior to the meeting.

1. **CALL TO ORDER**
2. **ROLL CALL/ESTABLISH QUORUM**
3. **FLAG SALUTE**
4. **APPROVAL OF AGENDA**
5. **PUBLIC COMMENTS and PUBLIC FORUM**

This item is for the public to discuss matters not on the agenda and within the jurisdiction of the District or to discuss the closed executive session item. Comments shall be limited to five minutes per person and twenty minutes for all comments unless otherwise authorized by the Board.
6. **OLD BUSINESS**
 - A. **PUBLIC HEARING: ORDINANCE 2022-001 INTENT TO ADOPT THE 2022 FIRE CODE, AS AMMENDED; INTRODUCTION AND SECOND READING OF ORDINANCE; SET PUBLIC HEARING FOR October 27, 2022**
7. **GOOD TO THE ORDER**
8. **NEXT SCHEDULED MEETING/AGENDA ITEMS**

November 9, 2022
9. **ADJOURNMENT**

Rescue Fire Department
ORDINANCE NO. 2022-01

BE IT ORDAINED BY THE BOARD OF DIRECTORS OF THE RESCUE FIRE DEPARTMENT AS FOLLOWS:

An ordinance of the Rescue Fire Department adopting the ~~2019-2022~~ Edition of the *California Fire Code*, incorporating the ~~2018-2021~~ Edition of the *International Fire Code*, regulating and governing the safeguarding of life and property from fire and explosion hazards arising from the storage, handling and use of hazardous substances, materials and devices, and from conditions hazardous to life or property in the occupancy of buildings and premises in the Rescue Fire Protection District (RFPD); providing for the issuance of permits and collection of fees therefor; Repealing Ordinance No. ~~2016-37~~2019-01 of the RFPD and all other ordinances and parts of the ordinances in conflict therewith.

Be it ORDAINED by the Board of Directors of the RFPD:

Section 1: **FINDINGS OF FACTS**

Section 2: **ADOPTION OF CODE WITH EXCLUSIONS**

Section 3: **LOCAL AMENDMENTS**

Section 4: **CONFLICT**

Section 5: **SEVERABILITY**

Section 6: **EFFECTIVE DATE AND PUBLICATION**

SECTION 1: FINDINGS OF FACTS

The Rescue Fire Department makes certain changes (listed below) to the *California Fire Code*, 2022 Edition, pursuant to *Health & Safety Code Sections 13869.7, 17958.5, 17958.7 and 18941.5* during this code adoption process. Such changes are necessary because of local climatic, geological and/or topographical conditions. The RFPD has adopted, pursuant to *Section 18941.5* of the *California Health & Safety Code*, the findings of facts relative to these conditions by Resolution #2022-XX of the Rescue Fire Department dated XXXX XX, 2022.

SECTION 2: ADOPTION OF CODE WITH EXCLUSIONS

The RFPD adopts the 2019-2022 California Fire Code, Title 24, Part 9, in its entirety, including Appendices, incorporating those sections of the *International Fire Code, 2018-2021* edition not adopted by the state, with the exclusions listed below:

Exclusions: 103, ~~105.6.39, 308.1.4,~~ 309, 311.5, 311.6, 318, ~~403.1, 403.2.1-403.2.4,~~ 403.3, ~~403.4, 403.5~~403.6, 403.7~~8,~~ ~~403.8 (adopting 403.8.1 403.8.1.7),~~ 403.9~~10,~~ 403.10.2, 403.10.3, 403.11, ~~403.12, 404.1-404.4~~404, 405.1-405.4, 405.6-405.9, 406, ~~805-807 (adopting 807.5.2), 808, 903.3.1.2,~~ 904.1.1, ~~1104,~~ 1103.1, 1103.3-1103.6~~4,~~ ~~1103.6-1103.9 (adopting 1103.9.1), 1103.10, 1104~~1105-1106, Chapter 25, Chapter 26, ~~the exceptions under D104.2 (Exception only), D106.1 (Exception only), D107.1 (Exceptions only), Appendix A, Appendix E, Appendix F,~~ Appendix G, Appendix J, Appendix K, Appendix L, Appendix M, Appendix N, Appendix O.

Formatted: Indent: First line: 0"

Appendices not adopted can be used for reference in enforcing other sections of the 2019 2022 California Fire Code.

SECTION 3: LOCAL AMENDMENTS TO THE 2022 CALIFORNIA FIRE CODE

The following Sections are hereby amended or added:

Chapter 1

SECTION 101.1 "TITLE" SHALL BE AMENDED AS FOLLOWS:

Section 101.1 TITLE. These regulations shall be known as the Fire Code of RFPD, hereinafter referred to as "this code".

SECTION 105.5 "REQUIRED OPERATIONAL PERMITS" IS AMENDED AS FOLLOWS:

Section 105.5 Required operational permits. The fire code official is authorized to issue operational permits for the operations set forth in Sections 105.5.2 through 105.5.5~~25.~~

Formatted: Strikethrough

SECTION 105.5.55 "AUTOMOBILE WRECKING YARDS" IS ADDED AS FOLLOWS:

Section 105.5.55 Automobile wrecking yards. An operational permit is required for the operation of automobile wrecking yards.

SECTION 105.6 "REQUIRED CONSTRUCTION PERMITS" IS AMENDED AS FOLLOWS:

Section 105.6 required construction permits. The fire code official is authorized to issue construction permits for work as set forth in sections 105.6.1 through 105.6.2~~46.~~

Formatted: Strikethrough

SECTION 105.6.25 "AUTOMOBILE WRECKING YARDS" IS ADDED AS FOLLOWS:

Section 105.6.25 Automobile wrecking yards. Construction permits are required for the installation of or modification to automobile wrecking yards.

SECTION 105.6.26 "TRAFFIC CALMING DEVICES" IS ADDED AS FOLLOWS:

105.6.26 Traffic calming devices. Construction permits are required for the installation or modification of traffic calming devices.

SECTION ~~106.6~~107.5 "PERMIT, PLAN REVIEW AND INSPECTION FEES" SHALL BE ADDED AS FOLLOWS:

Section ~~106.6~~107.5 Permit. –A schedule of fees adopted by the district board of directors for plan review, inspections and the issuance of permits by the district may be found in the most current district fee schedule (Health & Safety Code 17951).

SECTION ~~106.6-1~~107.5.1 "COST RECOVERY FEES" SHALL BE ADDED AS FOLLOWS:

Section ~~106.6-1~~107.5.1 Cost Recovery Fees. Fire service fees may be charged to any person, firm, corporation or business that through negligence, violation of the law, or as a result of carelessness, is responsible for the cause of the district to respond to the scene of an incident. A district board may charge a fee to cover the cost of any service which the district provides or the cost of enforcing any regulation for which the fee is charged (Health & Safety Code 13916). The fee shall not exceed the actual cost of suppressing the fire and/or responding to the scene of an incident.

SECTION ~~107-6~~7 "ADMINISTRATIVE COSTS" SHALL BE ADDED AS FOLLOWS:

Section ~~107-6~~7 Administrative Costs. When a test or inspection is scheduled, and the contractor fails to perform to the satisfaction of the authority having jurisdiction (AHJ), the AHJ may bill the contractor for actual time spent traveling to and from the test/inspection location and the time spent at the test/inspection site as well as administrative costs.

SECTION ~~109-4~~111.5 "APPEAL PROCEDURES AND TIMELINES" SHALL BE ADDED AS FOLLOWS:

Section ~~109-4~~111.5 Appeal Procedures and Timelines. Any person or entity who believes they may be adversely affected by an order, decision, or determination made by the fire code official through a written notice may appeal this matter within 15 calendar days of the postmark on the notice. All such appeals shall be filed in writing with the Secretary of the Governing Board for the district. A timely appeal shall stay further action by the fire code official until the matter is determined by the Appeal Board as outlined in Section 109.2, unless the issue poses an imminent fire or life safety hazard to members of the public. The fire code official shall notify the appellant by certified mail of the date and time of such hearing. The hearing shall be scheduled to take place no sooner than 20 calendar days from the date shown on the certified mail. The appellant shall have the right to appear in person or by agent at the hearing and present oral, written and/or photographic evidence to the Appeal Board.

SECTION 1129.4 "VIOLATION PENALTIES" SHALL BE AMENDED AS FOLLOWS:

Section 1129.4 Violation Penalties. Persons who shall violate a provision of this code or shall fail to comply with any of the requirements thereof or who shall erect, install, alter, repair or do work in violation of the approved construction documents or directive of the fire code official, or of a permit or certificate used under provisions of this code, shall be guilty of a *misdemeanor or infraction, at the discretion of the prosecuting attorney or agency*, punishable by a fine not more than \$100.00 for a first violation; A fine not exceeding \$500.00 for a second violation of the same provision within one year; A fine not exceeding \$1000.00 for each additional violation of the same provision within one year, or by imprisonment not exceeding 180 days, or both such fine and imprisonment. Each day that a violation continues after due notice has been served shall be deemed a separate offense. (*Health & Safety Code Sections 13145 and 17995*).

SECTION 1129.4.2 "CITATIONS" SHALL BE ADDED AS FOLLOWS:

Section 1129.4.2 Citations. *The Fire Chief, or his/her duly authorized representative, may issue citations for infractions or misdemeanor violations of this code pursuant to Section 13871 of the Health & Safety Code of the State of California and Chapter 5c (commencing with Section 853.6) of Title 3 of Part 2 of the Penal Code of the State of California.*

SECTION 1132.4 "FAILURE TO COMPLY" SHALL BE AMENDED AS FOLLOWS:

Section 1132.4 Failure to Comply. Any person who shall continue any work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be *punishable by a fine or imprisonment or both as described in Section 1129.4 (Health & Safety Code Sections 13145 and 17995)*.

Chapter 2

SECTION 202 "CAMPFIRE" SHALL BE ADDED AS FOLLOWS:

CAMPFIRE. ~~*Shall mean a fire which is used for cooking, personal warmth, lighting, or aesthetic purposes.—This includes fires contained within outdoor fireplaces and enclosed stoves with flues or chimneys, stoves using jellied, liquid, or solid fuels, portable barbecue pits, braziers, or space heating devices which are used outside of any structure, mobile home, or any living accommodation mounted on a vehicle. A fire which is used for cooking, personal warmth, lighting, or aesthetic purposes.*~~

SECTION 202 "DISTRICT" SHALL BE ADDED AS FOLLOWS:

DISTRICT. *The district and all other areas within the exterior boundaries thereof now or hereafter established.*

SECTION 202 "DRIVEWAY" SHALL BE ADDED AS FOLLOWS:

DRIVEWAY. *A vehicular access that serves up to two (2) parcels with no more than two (2) residential units and any number of non-commercial or industrial buildings on each parcel.*

SECTION 202 "EXECUTIVE BODY" SHALL BE ADDED AS FOLLOWS:

EXECUTIVE BODY. *The Board of Directors of the District.*

SECTION 202 "FIRE CHIEF" SHALL BE ADDED AS FOLLOWS:

FIRE CHIEF. *The Chief Executive Fire Officer of the Fire department/district serving the jurisdiction or a duly authorized representative.*

SECTION 202 "FIRE HAZARD" SHALL BE ADDED AS FOLLOWS:

FIRE HAZARD. *Any condition, arrangement, or act which will increase, or may cause an increase of, the hazard or menace of fire to a greater than customarily recognized as normal by persons in the public service of preventing, suppressing or extinguishing fire; or which may obstruct, delay, or hinder, or may become the cause of obstruction, delay or hinderance to the prevention, suppression, or extinguishment of fire.*

SECTION 202 "OPEN BURNING" SHALL BE AMENDED AS FOLLOWS:

OPEN BURNING. *The burning of materials wherein products of combustion are emitted directly into the ambient air without passing through a stack or chimney from an enclosed chamber. Open burning does not include road flares, smudge-pots and similar devices associated with safety or occupational uses typically considered open flames, recreational fires, or use of portable outdoor fireplaces. For the purpose of this definition, a chamber shall be regarded as enclosed when, during the time combustion occurs, only apertures, ducts, stacks, flues or chimneys necessary to provide combustion air and permit the escape of exhaust gas are open.*

Formatted: Strikethrough

Open burning shall also include campfires, bonfires, portable outdoor fireplaces, ceremonial fires, and recreational fire as defined in the Fire Code.

Exception:

1. *UL or ASMI listed LPG or natural gas outdoor flame devices, such as gas BBQ's or gas fire pits that comply with the Fire Code.*
2. *For one-or two-family dwellings, fixed or portable outdoor flame devices that meet the following:*
 - a. Devices shall comply with the Fire Code.*
 - b. Devices shall be used per manufacturer's specifications.*
 - c. Minimum 10-foot clearance from device to all flammable material and vegetation.*
 - d. No burning shall be conducted during high or extreme fire weather conditions (e.g., National Weather Service Red Flag Warnings).*
3. *Campfires on private lands. Where required by the fire code official, a permit shall be issued by the fire code official.*
4. *Ceremonial and/or religious burning with the following safety measures:*
 - a. Maximum 4-foot x 4-foot burn area.*

- b. Minimum 10-foot clearance from edge of burn area to all flammable material and vegetation.
- c. An approved water supply is located within 500-feet of the burn area.
- d. The burn area is located no less than 30-feet from adjoining property lines.
- e. An adult is present with a shovel until the fire is extinguished.
- f. No burning shall be conducted during high or extreme fire weather conditions (e.g., National Weather Service Red Flag Warnings).

SECTION 202 "TRAINED CROWD MANAGER" SHALL BE ADDED AS FOLLOWS:

TRAINED CROWD MANAGER. *Standby personnel, usually a security guard or usher personnel, who are trained in the proper procedure to exit people from a tent or other place of public assemblage in an orderly and calm fashion in the event of an emergency*

Chapter 3

SECTION 302.1 "DEFINITIONS" SHALL BE AMENDED AS FOLLOWS:

- 3D PRINTER.
- ADDITIVE MANUFACTURING.
- BONFIRE.
- CAMPFIRE.
- HI-BOY.
- HIGH-VOLTAGE TRANSMISSION LINE.
- OPEN BURNING.
- PORTABLE OUTDOOR FIREPLACE.
- POWERED INDUSTRIAL TRUCK.
- RECREATIONAL FIRE.
- SKY LATTERN.

Formatted: Font: Not Italic

SECTION 307.4.4 "~~OPEN BURNING~~ ~~CAMPFIRE~~-RESTRICTIONS" SHALL BE ADDED AS FOLLOWS:

Section 307.4.4 Open Burning, Restrictions. *Open burning on all lands within the jurisdiction of the Rescue Fire Department, including the Local Response Area (LRA), is prohibited when the California Department of Forestry and Fire Protection (Cal Fire) issues a burn suspension in the State Responsibility Area (SRA). This prohibition shall be made effective 24-hours following its commencement in the SRA.*

Open burning is also prohibited on all lands within the jurisdiction of Rescue Fire Department at any time the fire code official that atmospheric conditions or other local circumstances make such fires hazardous, including factors such as high winds, low fuel moisture, fire weather, the issuance of red flag warnings, severe threat of wildland fire, or present risk of destruction by wildfire to life, wildlife, property, or natural resources.

Formatted: Font: Italic

~~**307.4.4.1** It is unlawful for any person to light, maintain, or use a campfire upon or near any brush-covered land, grass-covered land, or forest covered land during the time when burning~~

~~permits are suspended by the Director of the Department of Forestry and Fire Protection, the CAL FIRE Unit Chief, or the AHJ.~~

~~**Exception:** Commercial cooking operations with approval of the AHJ.~~

~~**307.4.4.2** When campfires are allowed, it should be unlawful for any person to light, maintain, or use a campfire upon any brush-covered land, grass-covered land, or forest-covered land unless the following minimum requirements are complied with.~~

~~**307.4.4.2 (a)** The area within 5 feet of the periphery of the campfire is cleared of all flammable material and vegetation.~~

~~**307.4.4.2 (b)** One serviceable shovel with a handle of at least 12 inches is ready for use at the immediate area of the campfire.~~

~~**307.4.4.2 (c)** Campfires shall be limited to a 1 foot by 1 foot area, unless in an approved manufactured cooking device or fire ring.~~

~~**307.4.4.2 (d)** Written permission of the landowner must be obtained prior to the ignition of the campfire and shall be on-site.~~

Chapter 4

SECTION 401.2.1 "PRE-FIRE PLANS" IS ADDED AS FOLLOWS:

Section 401.2.1 Pre-fire plans. Where required by the fire code official, a pre-fire plan shall be provided and approved by the fire code official for all new commercial structures.

Chapter 5

SECTION 503.2.1 "DIMENSIONS" SHALL BE AMENDED AS FOLLOWS:

Section 503.2.1 Dimensions. Fire apparatus access roads shall have an unobstructed width of not less than 20 feet (6096 mm), exclusive of shoulders, *as measured from face of curb to face of curb*, except for approved security gates in accordance with Section 503.6, and an unobstructed vertical clearance of not less than 15 feet. ~~All Driveways in the district shall not *behave an unobstructed width of not* less than 12 feet wide.~~

SECTION 503.2.5 "DEAD ENDS" SHALL BE AMENDED AS FOLLOWS:

Section 503.2.5 Dead Ends. Dead-end fire apparatus access roads *and driveways* in excess of 150 feet (45,720 mm) in length shall be provided with an approved area for turning around fire apparatus.

SECTION 503.2.6 "BRIDGES AND ELEVATED SURFACES" SHALL BE AMENDED AS FOLLOWS:

Section 503.2.6 Bridges and Elevated Surfaces. Where a bridge or an elevated surface is part of a fire apparatus access road, the bridge shall be constructed and maintained in accordance with AASHTO HB-17, *the current El Dorado County Transportation Division Bridge*

Standard or Appendix D of the current California Fire Code, whichever is more restrictive. Bridges and elevated surfaces shall be designed for a live load sufficient to carry the imposed loads of fire apparatus. Vehicle load limits shall be posted at both entrances to bridges when required by the fire code official. Where elevated surfaces designed for emergency vehicle use are adjacent to surfaces that are not designed for such use, approved barriers, approved signs or both shall be installed and maintained where required by the fire code official.

SECTION 503.~~3.14.2~~ "NO PARKING IN FIRE LANES" SHALL BE ADDED AS FOLLOWS:

Section 503.~~3.14.2~~ No Parking In Fire Lanes. *No person shall stop, park, or leave standing any vehicle, whether attended or unattended, except when necessary to avoid conflict with other traffic or in compliance with the directions of the Fire Chief, or his/her duly authorized representative, Peace Officer or official traffic control device along the edge of any highway, at any curb, or in any location in a publicly or privately owned or operated off-street parking facility, designated as a fire lane by the district with jurisdiction over the area in which the place is located. The designation shall be indicated (1) by a sign posted immediately adjacent to, and visible from, the designated place clearly stating in letters not less than one inch in height that the place is a fire lane, (2) by outlining or painting the place in red and, in contrasting color, marking the place with the words "FIRE LANE", which are clearly visible from a vehicle, or (3) by a red curb or red paint on the edge of the roadway upon which is clearly marked the words "FIRE LANE".*

SECTION 503.~~3.24.3~~ "NO PARKING IN FRONT OF HYDRANTS" SHALL BE ADDED AS FOLLOWS:

Section 503.~~3.24.3~~ No Parking in Front of Hydrants. *No person shall stop, park, or leave standing any vehicle within 15 feet of a fire hydrant except as follows: (a) If the vehicle is attended by a licensed driver who is seated in the front seat and who can immediately move such vehicle in case of necessity, (b) If the vehicle is owned or operated by a fire department and is clearly marked as a fire department vehicle.*

SECTION 503.~~3.34.4~~ "FIRE LANES BASED ON ROAD WIDTH" SHALL BE ADDED AS FOLLOWS:

Section 503.~~3.34.4~~ Fire Lanes Based on Road Width. *Fire lanes shall be based on road width as required in Appendix D as amended by the District.*

~~SECTION 503.5.3 "FIRE APPARATUS ACCESS GATES" SHALL BE ADDED AS FOLLOWS:~~

~~*All automatic and manual gates installed over fire apparatus access roads shall comply with the district gate standard as approved by the fire code official.*~~

~~SECTION 503.6 "SECURITY GATES" IS AMENDED AS FOLLOWS:~~

~~**Section 503.6 Security Gates.** *The installation of security gates across a fire apparatus access road shall be approved by the fire code official and shall comply with the District gate standard. Where security gates are installed, they shall have an approved means of emergency operation. The security gates and the emergency operation shall be maintained operational at all times. Electric gate operators, where provided, shall be listed in accordance*~~

Formatted: Font: Italic

with UL 325. Gates intended for automatic operation shall be designed, constructed, and installed to comply with the requirements of ASTM F2200.

SECTION 505.1 "ADDRESS IDENTIFICATION" SHALL ~~BE HAVE THE FIRST LINE OF THIS PARAGRAPH~~ AMENDED AS FOLLOWS:

Section 505.1 Address Identification. ~~Addresses for new and existing buildings shall comply with the District address standard as approved by the fire code official. New and existing buildings shall be provided with approved address identification.~~ The address identification shall be legible and placed in a position that is visible from the street or road fronting the property. Address identification characters shall contrast with their background. Address numbers shall be Arabic numbers or alphabetical letters. Numbers shall not be spelled out. Each character shall be not less than 4 inches (102 mm) high with a minimum stroke width of 1/2 inch (12.7 mm). Where required by the fire code official, address identification shall be provided in additional approved locations to facilitate emergency response. ~~access is by means of a private road and the building cannot be viewed from the public way, a monument, pole or other sign or means shall be used to identify the structure. Address identification shall be maintained.~~

Formatted: Font: (Default) Arial, 12 pt, Strikethrough
Formatted: Font: (Default) Arial, 12 pt, Strikethrough
Formatted: Font: (Default) Arial, 12 pt, Strikethrough

SECTION 507.5.1 "WHERE REQUIRED" SHALL BE AMENDED AS FOLLOWS:

Section 507.5.1 Where Required. ~~400 feet shall be amended to 150 feet. Where a portion of the facility or building hereafter constructed or moved into or within the jurisdiction is more than 150 feet (422 mm) from a hydrant on a fire apparatus access road, as measured by an approved route around the exterior of the facility or building, on-site fire hydrants and mains capable of supplying the required fire flow shall be provided where required by the fire code official.~~

Formatted: Strikethrough
Formatted: Strikethrough
Formatted: Strikethrough

Exceptions:

1. For Group R-3 and Group U occupancies, the distance requirement shall be 600 feet (183 m).
2. For buildings equipped throughout with an approved automatic sprinkler system installed in accordance with Section 903.3.1.1, 903.3.1.2, or 903.3.1.3, the distance requirement shall be not more than 600 feet (183 m).

Formatted: Strikethrough

SECTION 509.3 "FIRE CONTROL ROOM" SHALL BE ADDED AS FOLLOWS:

Section 509.3 Fire Control Room. Fire sprinkler risers, fire alarm control panels, solar photovoltaic power system rapid shutoff switches, and other fire detection, suppression or similar control elements shall be located inside a single fire control room for the building. The fire control room shall have minimum dimensions of five feet by seven feet in size with a total usable area of not less than 35 square feet. The room shall be located within the building on an outside wall at a location approved by the Fire Code Official and shall be accessible from the exterior. An exterior access door with a clear width of not less than 32 inches and height of not less than 80 inches shall be provided for access into the room. A durable sign shall be affixed to the exterior of the door with the words "FIRE CONTROL ROOM" in letters not less than 4 inches in height. A key box complying with Section 506 shall be installed on the exterior side of the fire control room door opening.

The room must be capable of maintaining a minimum temperature of 40 degrees Fahrenheit. A clearance of 12 inches shall be provided from the fire sprinkler risers to any adjacent walls.

This room can be a shared with other building utilities or fire protection equipment that is not incompatible. An approved cabinet or container shall be provided to store record plans of the fire sprinkler system and other fire protection equipment. This room shall not be used for any other storage.

Exception: One-and two-family dwellings, manufactured homes or similar uses defined as either a Group R-3, R3.1, or R-4 occupancy.

SECTION 510.4.2.3 “STANDBY POWER” SHALL BE AMENDED AS FOLLOWS:

Section 510.4.2.3 Standby power. In-building, two-way emergency responder communication radio coverage systems shall be provided with dedicated standby batteries or provided with 2-hour standby batteries and connected to the facility generator power system in accordance with Section 1203. The standby power supply shall be capable of operating the in-building, two-way emergency responder communication coverage system at 100-percent system capacity for a duration of not less than 472 hours.

Formatted: No underline, Strikethrough

Chapter 9

SECTION 903.2 “WHERE REQUIRED” SHALL BE AMENDED AS FOLLOWS:

Section 903.2 Where Required. ~~An approved automatic sprinkler systems shall be required and installed in new buildings and structures 3600 square feet or greater when constructed or relocated within the jurisdiction shall be provided in the locations as~~ described in Sections 903.2.1 through 903.2.12 ~~and Sections 903.2.14 through 903.2.2423.~~

Formatted: Strikethrough

Exception: Agricultural buildings not under a special use permit used for commercial purposes.

SECTION 903.2.1 GROUP A SHALL BE AMENDED AS FOLLOWS FOR A GROUPS A-1 THROUGH A-4: 903.2.1.1 ~~(1) The fire area exceeds 3,600 square feet.~~

SECTION 903.2.1.1 “GROUP A-1” SHALL BE AMENDED AS FOLLOWS:

Section 903.2.1.1 Group A. An automatic sprinkler system shall be provided throughout stories containing Group A-1 occupancies and throughout all stories from the Group A-1 occupancy to and including the levels of exit discharge serving that occupancy where one of the following conditions exists:

Formatted: Strikethrough

Formatted: Strikethrough

Formatted: Strikethrough

1. The fire area exceeds 12,000 3,600 square feet (1115 m²).
2. The fire area has an occupant load of 300 or more.
3. The fire area is located on a floor other than a level of exit discharge serving such occupancies.
4. The fire area contains a multi-theater complex

SECTION 903.2.1.2 “GROUP A-2” SHALL BE AMENDED AS FOLLOWS:

Section 903.2.1.2 Group A-2. An automatic sprinkler system shall be provided throughout stories containing Group A-2 occupancies and throughout all stories from the Group A-2 occupancy to and including the levels of exit discharge serving that occupancy where one of the following conditions exists:

1. The fire area exceeds ~~5,000~~ 3,600 square feet (~~464 m²~~);
2. The fire area has an occupant load of 100 or more.
3. The fire area is located on a floor other than a level of exit discharge serving such occupancies.
4. The structure exceeds ~~5,000~~ 3,600 square feet (~~464 m²~~), contains more than one fire area containing a Group A-2 occupancy, and is separated into two or more buildings by fire walls of less than 4-hour fire-resistance rating without openings.

Formatted: Strikethrough

Formatted: Strikethrough

Formatted: Strikethrough

Formatted: Font: Italic

Formatted: Strikethrough

SECTION 903.2.1.3 "GROUP A-3" SHALL BE AMENDED AS FOLLOWS:

Section 903.2.1.3 Group A-3. An automatic sprinkler system shall be provided throughout stories containing Group A-3 occupancies and throughout all stories from the Group A-3 occupancy to and including the levels of exit discharge serving that occupancy where one of the following conditions exists:

1. The fire area exceeds ~~12,000~~ 3,600 square feet (~~1115 m²~~).
2. The fire area has an occupant load of 300 or more.
3. The fire area is located on a floor other than a level of exit discharge serving such occupancies.
4. The structure exceeds ~~12,000~~ 3,600 square feet (~~1115 m²~~), contains more than one fire area containing exhibition and display rooms, and is separated into two or more buildings by fire walls of less than 4-hour fire-resistance rating without openings.

Formatted: Strikethrough

Formatted: Strikethrough

Formatted: Strikethrough

Formatted: Strikethrough

Formatted: Strikethrough

Formatted: Strikethrough

SECTION 903.2.1.4 "GROUP A-4" SHALL BE AMENDED AS FOLLOWS:

Section 903.2.1.4 Group A-4. An automatic sprinkler system shall be provided throughout stories containing Group A-4 occupancies and throughout all stories from the Group A-4 occupancy to and including the levels of exit discharge serving that occupancy where one of the following conditions exists:

1. The fire area exceeds ~~12,000~~ 3,600 square feet (~~1115 m²~~).
2. The fire area has an occupant load of 300 or more.
3. The fire area is located on a floor other than a level of exit discharge serving such occupancies.

~~SECTION 903.2.3 GROUP E SHALL BE AMENDED AS FOLLOWS: 903.2.3 (1) THROUGHOUT ALL GROUP E~~ fire areas greater than ~~3,600 square feet~~ in area.

SECTION 903.2.3 "GROUP E" SHALL BE AMENDED AS FOLLOWS:

Section 903.2.3 Group E. An automatic sprinkler system shall be provided for Group E occupancies as follows:

1. Throughout all Group E fire areas greater than ~~12,000~~ 3,600 square feet (~~1115 m²~~) in area.
2. The Group E fire area is located on a floor other than a level of exit discharge serving such occupancies.

Formatted: Strikethrough

Formatted: Strikethrough

Formatted: Strikethrough

Exception: In buildings where every classroom has not fewer than one exterior exit door at ground level, an automatic sprinkler system is not required in any area below the lowest level of exit discharge serving that area.

3. The Group E fire area has an occupant load of 300 or more.
4. In rooms or areas with special hazards such as laboratories, vocational shops and other such areas where hazardous materials in quantities not exceeding the maximum allowable quantity are used or stored.
5. Throughout any Group E structure greater than ~~12,000~~ 3,600 square feet (~~1115 m²~~) in area, which contains more than one fire area, and which is separated into two or more buildings by fire walls of less than 4-hour fire resistance rating without openings.
6. For public school state funded construction projects see Section 903.2.19.
7. For public school campuses, Kindergarten through 12th grade, see Section 903.2.20

Formatted: Strikethrough
Formatted: Strikethrough
Formatted: Strikethrough

SECTION 903.2.4 GROUP F-1 SHALL BE AMENDED AS FOLLOWS: 903.2.4 GROUP F, 903.2.4 (1) A Group F fire area exceeds ~~3,600~~ square feet.

SECTION 903.2.4 "GROUP F-1" SHALL BE AMENDED AS FOLLOWS:

Section 903.2.4 Group F-1. An automatic sprinkler system shall be provided throughout all buildings containing a Group F-1 occupancy where one of the following conditions exists:

1. A Group F-1 fire area exceeds ~~3,600~~ 12,000 square feet (~~1155 m²~~).
2. A Group F-1 fire area is located more than three stories above grade plane.
3. The combined area of all Group F-1 fire areas on all floors, including any mezzanines, exceeds ~~3,600~~ 24,000 square feet (~~1155 m²~~).

Formatted: Font: Italic
Formatted: Strikethrough
Formatted: Strikethrough
Formatted: Strikethrough
Formatted: Strikethrough

SECTION 903.2.7 GROUP M SHALL BE AMENDED AS FOLLOWS: 903.2.7 GROUP B AND M. 903.2.7 (1) A Group B and M fire area exceeds ~~3,600~~ square feet. SECTION 903.2.7 GROUP M SHALL BE AMENDED AS FOLLOWS: 903.2.7 GROUP B AND M. 903.2.7 (1) A Group B and M fire area exceeds ~~3,600~~ square feet.

SECTION 903.2.7 "GROUP M" SHALL BE AMENDED AS FOLLOWS:

Section 903.2.7 Group M. An automatic sprinkler system shall be provided throughout buildings containing a Group M occupancy where one of the following conditions exists:

1. A Group M fire area exceeds ~~12,000~~ 3,600 square feet (~~1115 m²~~).
2. A Group M fire area is located more than three stories above grade plane.
3. The combined area of all Group M fire areas on all floors, including any mezzanines, exceeds ~~24,000~~ 3,600 square feet (2230 m²).
5. The structure exceeds ~~12,000~~ 3,600 square feet (~~1115 m²~~), contains more than one fire area containing a Group M occupancy, and is separated into two or more buildings by fire walls of less than 4-hour fire resistance rating without openings.

Formatted: Strikethrough
Formatted: Strikethrough
Formatted: Strikethrough
Formatted: Strikethrough
Formatted: Strikethrough
Formatted: Strikethrough
Formatted: Strikethrough
Formatted: Numbered + Level: 1 + Numbering Style: 1, 2, 3, ... + Start at: 5 + Alignment: Left + Aligned at: 0.25" + Indent at: 0.5"

SECTION 903.2.7.2 "GROUP M UPHOLSTERED FURNITURE OR MATTRESSES" SHALL BE AMENDED AS FOLLOWS:

Section 903.2.7.2 Group M Upholstered Furniture or Mattresses. An automatic sprinkler system shall be provided throughout a Group M fire area where the area used for the display and sale of upholstered furniture or mattresses exceeds ~~5,000~~ 3,600 square feet ~~(464 m²)~~.

Formatted: No underline, Strikethrough

Formatted: No underline, Strikethrough

SECTION 903.2.8.52 "MANUFACTURED HOMES" SHALL BE ADDED AS FOLLOWS:

Section 903.2.8.5 Manufactured Homes. *An automatic fire sprinkler system shall be required in all new manufactured homes and multi-family manufactured homes intended for use as a one-and two-family dwelling. The design and installation of such systems shall be in accordance with California Code of Regulations, Title 25, §4300.*

Exceptions:

1. *Manufactured homes located within an existing mobile home park complying with California Health and Safety Code, Division 13, Part 2.1 or 2.3.*
2. *Manufactured homes that do not exceed 1,200 square feet in size and serve as an accessory dwelling unit, as defined in Government Code Section 658502; when the existing primary residence on the property is not required to comply with California Residential Code Section R313.2.*
3. *Manufactured homes that do not exceed 320 square feet in size.*

~~Section 903.2.9 Group S-1 shall be amended as follows: 903.2.9 Group S. 903.2.9 (1) A Group S fire area exceeds 3,600 square feet.~~

SECTION 903.2.9 "GROUP S-1" SHALL BE AMENDED AS FOLLOWS:

Section 903.2.9 Group S-1. An automatic sprinkler system shall be provided throughout all buildings containing a Group S-1 occupancy where one of the following conditions exists:

1. A Group S-1 fire area exceeds ~~12,000~~ 3,600 square feet ~~(1115 m²)~~.
2. A Group S-1 fire area is located more than three stories above grade plane.
3. The combined area of all Group S-1 fire areas on all floors, including any mezzanines, exceeds ~~24,000~~ 3,600 square feet ~~(2430 m²)~~.
4. A Group S-1 fire area used for the storage of commercial motor vehicles where the fire area exceeds ~~5,000~~ 3,600 square feet ~~(464 m²)~~.

Formatted: Strikethrough

Formatted: Strikethrough

Formatted: Strikethrough

Formatted: Strikethrough

Formatted: Strikethrough

Formatted: Strikethrough

~~Section 903.2.10 Group S-2 Enclosed Parking Garages shall be amended as follows: 903.2.10 (1) Where the fire area of the enclosed parking garage exceeds 3,600 square feet.~~

SECTION 903.2.10 "GROUP S-2" SHALL BE AMENDED AS FOLLOWS:

Section 903.2.10 Group S-2. An automatic sprinkler system shall be provided throughout buildings classified as parking garages where any of the following conditions exist:

1. Where the fire area of the enclosed parking garage, in accordance with Section 406.6 of the California Building Code, exceeds ~~12,000~~ 3,600 square feet ~~(1115 m²)~~.
2. Where the enclosed parking garage, in accordance with Section 406.6 of the California Building Code, is located beneath other groups.

Formatted: Strikethrough

Formatted: Font: Not Italic

Formatted: Strikethrough

Exception: Enclosed parking garages located beneath Group R-3 occupancies.

3. ~~Where the fire area of the open parking garage, in accordance with Section 406.5 of the California Building Code, exceeds 48,000 3,600 square feet (4460 m²).~~

Formatted: Strikethrough

Formatted: Strikethrough

SECTION 903.2.10.1 "COMMERCIAL PARKING GARAGES" SHALL BE AMENDED AS FOLLOWS:

Section 903.2.10.1 Commercial Parking Garages. ~~An automatic sprinkler system shall be provided throughout buildings used for storage of commercial motor vehicles where the fire area exceeds 5,000 3,600 square feet (464 m²).~~

Formatted: Strikethrough

Formatted: Font: Italic

Formatted: Strikethrough

SECTION 903.2.22 "GROUP B" SHALL BE ADDED AS FOLLOWS:

Section 903.2.22 Group B. *An automatic sprinkler system shall be provided throughout all buildings containing Group B occupancies where the fire area exceeds 3,600 square feet.*

SECTION 903.2.23 "GROUP F-2" SHALL BE ADDED AS FOLLOWS:

Section 903.2.23 Group F-2. *An automatic sprinkler system shall be provided throughout all buildings containing Group F-2 occupancies where the fire area exceeds 3,600 square feet.*

SECTION 903.6 "WHERE REQUIRED IN EXISTING BUILDINGS AND STRUCTURES" IS AMENDED AS FOLLOWS:

Section 903.6 Where Required In Existing Buildings and Structures. ~~An automatic sprinkler system shall be provided in existing buildings and structures where required in Chapter 11 and as follows:~~

1. ~~When there is a change in occupancy classification that results in an increased life safety or fire risk, as determined by the fire code official, and the structure exceeds 3,600 square feet, an automatic fire sprinkler system shall be installed throughout the building.~~

2. ~~In existing buildings 3,600 square feet or greater, other than one and two-family dwelling units, and agricultural buildings not under special use permit for commercial purposes, where the floor area of the building or structure is increased by an addition of more than thirty percent (30%) or 1,000 square feet whichever is less, such building or structure shall be made to conform to Section 903.2.~~

Formatted: Strikethrough

Formatted: Font: Not Italic

Exception: *When the building increase is less than 500 square feet.*

Formatted: Normal, Indent: Left: 0.5", No bullets or numbering

3. ~~In existing buildings 3,600 square feet or less, other than one-and two-family dwelling units, and agricultural buildings not under special use permit for commercial purposes, where the floor area of the building or structure is increased to a total square footage over 3,600 square feet, by an addition of more than thirty percent (30%) or 1,000 square feet, whichever is less, such building or structure shall be made to conform to Section 903.2.~~

Formatted: Strikethrough

Formatted: Font: Not Italic

Exception: *When the building increase is less than 500 square feet.*

SECTION 903.2A WHERE REQUIRED SHALL BE ADDED AS FOLLOWS:

~~Status of existing buildings greater than 3,600 square feet. In existing buildings 3,600 square foot or greater, other than one and two-family dwelling units, and agricultural buildings not under special use permit for commercial purposes, where the floor area of the building or structure is increased by an addition of more than thirty percent (30%) or 1,000 square feet whichever is less, such building or structure shall be made to conform to Section 903.2.~~

~~SECTION 907.2.A "WHERE REQUIRED – NEW BUILDINGS AND OR STRUCTURES" LESS THAN 3,600 SQUARE FEET SHALL BE ADDED-AMENDED AS FOLLOWS:~~

~~Section 907.2.a Where Required – New Buildings and or Structures. An approved fire alarm system installed in accordance with the provisions of this code and NFPA 72 shall be provided in new buildings and structures in accordance with Sections 907.2.1 through 907.2.2930 and provide occupant notification in accordance with Section 907.5, unless other requirements are provided by another section of this code.~~

Formatted: Strikethrough

~~Not fewer than one manual fire alarm box shall be provided in an approved location to initiate a fire alarm signal for fire alarm systems employing automatic fire detectors or waterflow detection devices. Where other sections of this code allow elimination of fire alarm boxes due to sprinklers or automatic fire alarm systems, a single fire alarm box shall be installed at a location approved by the enforcing agency.~~

Exceptions:

- ~~1. The manual fire alarm box is not required for fire alarm control units systems dedicated to elevator recall control, supervisory service and fire sprinkler monitoring.~~
- ~~2. The manual fire alarm box is not required for Group R-2 occupancies unless required by the fire code official to provide a means for fire watch personnel to initiate an alarm during a sprinkler system, impairment event. Where provided, the manual fire alarm box shall not be located in an area that is open to the public.~~
- ~~3. The manual fire alarm box is not required to be installed when approved by the fire code official.~~
- ~~4. A fire alarm system is not required in one and two-family dwellings, agricultural buildings, and other occupancies classified as Group U not under special use permit and/or not used for commercial purposes (e.g. retail sales, food service, and/or special events).~~
- ~~5. Buildings with a floor area less than 500 square feet may be exempt, as determined by the fire code official based on building construction material and features, location, occupancy type, and distance to exposures.~~

Formatted: Font: Italic

Formatted: Font: Italic

Formatted: Font: Italic

Formatted: Font: Italic

Formatted: Font: (Default) Arial, 12 pt

~~An approved fire alarm/detection system shall be installed in all buildings with a floor area less than 3,600 square foot.~~

Exceptions:

- ~~4. One and two-family dwellings (R-3 Occupancies and other occupancies classified as "U").~~
- ~~5. Agricultural buildings not under special use permit and/or not used for commercial purposes (e.g., retails sales, food service, and/or special events). Buildings with a floor area less than 500 square foot may be exempt, as determined by the Fire Chief, or his/her duly authorized representative, based on building construction material~~

Formatted: Normal, Indent: Left: 0"

Formatted: Normal, No bullets or numbering

~~and features, location, occupancy type, and distance to exposures.~~ SECTION 907.2.1.4 "GROUP A UNDER 3,600 SQUARE FEET" SHALL BE ADDED AS FOLLOWS:

Section 907.2.1.4 Group A Under 3,600 Square Feet. An approved fire alarm system shall be installed in all group A buildings with a floor area less than 3,600 square feet.

SECTION 907.2.2.3 "GROUP B UNDER 3,600 SQUARE FEET" SHALL BE ADDED AS FOLLOWS:

Section 907.2.2.3 Group B Under 3,600 Square Feet. An approved fire alarm system shall be installed in all group B buildings with a floor area less than 3,600 square feet.

SECTION 907.2.3.11 "GROUP E UNDER 3,600 SQUARE FEET" SHALL BE ADDED AS FOLLOWS:

Section 907.2.3.11 Group E Under 3,600 Square Feet. An approved fire alarm system shall be installed in all group E buildings with a floor area less than 3,600 square feet.

SECTION 907.2.4.1 "GROUP F UNDER 3,600 SQUARE FEET" SHALL BE ADDED AS FOLLOWS:

Section 907.2.4.1 Group F Under 3,600 Square Feet. An approved fire alarm system shall be installed in all group F buildings with a floor area less than 3,600 square feet.

SECTION 907.2.5.2 "GROUP H UNDER 3,600 SQUARE FEET" SHALL BE ADDED AS FOLLOWS:

Section 907.2.5.2 Group H Under 3,600 Square Feet. An approved fire alarm system shall be installed in all group H buildings with a floor area less than 3,600 square feet.

SECTION 907.2.6.6 "GROUP I UNDER 3,600 SQUARE FEET" SHALL BE ADDED AS FOLLOWS:

Section 907.2.6.6 Group I Under 3,600 Square Feet. An approved fire alarm system shall be installed in all group I buildings with a floor area less than 3,600 square feet.

SECTION 907.2.7.2 "GROUP M UNDER 3,600 SQUARE FEET" SHALL BE ADDED AS FOLLOWS:

Section 907.2.7.2 Group M Under 3,600 Square Feet. An approved fire alarm system shall be installed in all group M buildings with a floor area less than 3,600 square feet.

SECTION 907.2.8.4 "GROUP R-1 UNDER 3,600 SQUARE FEET" SHALL BE ADDED AS FOLLOWS:

Section 907.2.8.4 Group R-1 Under 3,600 Square Feet. An approved fire alarm system shall be installed in all group R-1 buildings with a floor area less than 3,600 square feet.

SECTION 907.2.9.4 "GROUP R-2, R-2.1, R-2.2 UNDER 3,600 SQUARE FEET" SHALL BE ADDED AS FOLLOWS:

Section 907.2.9.4 Group R-2, R-2.1, R-2.2 Under 3,600 Square Feet. An approved fire alarm system shall be installed in all group R-2, R-2.1, R-2.2 buildings with a floor area less than 3,600 square feet.

SECTION 907.2.10.1 "GROUP S UNDER 3,600 SQUARE FEET" SHALL BE ADDED AS FOLLOWS:

Section 907.2.10.1 Group S Under 3,600 Square Feet. An approved fire alarm system shall be installed in all group S buildings with a floor area less than 3,600 square feet.

907.2.~~30D~~ "TYPE I HOOD INSTALLATIONS" SHALL BE ADDED AS FOLLOWS:

907.2.~~30d~~ "Type I Hood Installations. *The requirement of installation, or replacement, of a Type I Hood System shall require a fire alarm/sprinkler monitoring system to be installed, or for the hood system to be connected to an existing fire alarm/sprinkler monitoring system for that building.*

907.~~6.52-C~~ "MONITORING" SHALL BE AMENDED ~~ADDED~~ AS FOLLOWS:

907.~~6.52-c~~ Monitoring. Fire alarm systems required by this chapter or by the California Building Code shall be monitored by an~~All fire alarm/detection systems shall be connected directly through and monitored by a UL approved, UL certified, Type A Full Service~~ central, proprietary or remote station service, which gives audible and visual signals at a constantly attended location. All sprinklered buildings shall be monitored.

Exceptions:

1. One- and two-family dwellings (R-3 Occupancies and other occupancies classified as "U").
2. Agricultural buildings not under special use permit and/or not used for commercial purposes (e.g., retail sales, food service, and/or special events).

SECTION 907.6.2.1 "SECONDARY POWER SUPPLY" SHALL BE ADDED AS FOLLOWS:

SECTION 907.6.2.1 SECONDARY POWER SUPPLY. ~~#-Where required by the fire code official,~~ in accordance with NFPA 72, the secondary power supply providing a minimum 24-hour power capacity under quiescent load (system operating in a non-alarm condition) shall be amended to a minimum 72-hour power capacity.

Exception: *The existence of an emergency back-up power supply that meets or exceeds the requirements of California Fire Code Chapter 12.*

~~SECTION 907.92-B~~ SECTION 907.92-B STATUS OF "WHERE REQUIRED IN EXISTING BUILDINGS" SHALL BE ADDED-AMENDED AS FOLLOWS:

SECTION 907.9 Where Required. An approved fire alarm system shall be provided in existing buildings and structures where required in Chapter 11 and ~~in~~ existing buildings with a floor area less than 3,600 square feet without an approved automatic sprinkler system, other than one- or two-family dwelling units, agricultural building not under special use permit for commercial purposes where a fire alarm detection system does not exist and the floor area of

~~the building or structure is increased or modified by more than thirty percent (30%) or 1,000 square feet, whichever is less, such building or structure shall be made to conform to Section 907 when required by the Fire Chief, or his/her duly authorized representative. Buildings with a floor area less than 500 square feet may be exempt, as determined by the Fire Chief, or his/her duly authorized representative, based on building construction materials and features, location, occupancy type, and distance to exposures.~~

~~**Exception:** When the building increase is less than 500 square feet.~~

Chapter 12

SECTION 1203.1.3 "INSTALLATION" SHALL BE AMENDED AS FOLLOWS:

Section 1203.1.3 Installation. Emergency power systems and standby power systems shall be installed in accordance with the California Building Code, the California Electrical Code, NFPA 110 and NFPA 111. ~~All buildings, other than one- and two-family dwelling units, and agricultural buildings not used for commercial purposes, with standby power, shall have a shunt trip device that disconnects all power sources to the building, approved by the fire code official. Existing installations shall be maintained in accordance with the original approval.~~

Chapter 33

SECTION 331~~10~~.3 "PREMISE IDENTIFICATION" SHALL BE ADDED AS FOLLOWS:

Section 331~~10~~.3 Premise Identification ~~Prior to and during construction, an approved address sign shall be provided at each fire and emergency vehicle access road entry into the project.~~

~~**3312.1 When Required** shall be amended as follows: Prior to combustible materials arriving on site, the fire hydrant water system shall be installed and maintained in continuous operation. The amount of water supplied shall meet the required fire flow for the project.~~

SECTION 331~~32~~.1 "WHEN REQUIRED" SHALL BE AMENDED AS FOLLOWS:

~~**Section 331~~32~~.1 When Required.** An approved water supply for fire protection, either temporary or permanent, shall be installed and maintained in continuous operation as soon as combustible building materials arrive on site, the commencement of vertical combustible construction and on installation of a standpipe system in buildings under construction, in accordance with Sections 3313.2 through 3313.5.~~

Formatted: Font: Bold, Strikethrough

~~**Exception:** The fire code official is authorized to reduce the fire-flow requirements for isolated buildings or a group of buildings in rural areas or small communities where the development of full fire-flow requirements is impractical.~~

Chapter 49

~~Section 4903 Plans~~

~~**4903.1 Where Required** shall be added as follows: The fire code official of the EDHCWD may require development projects located in Moderate, High and Very-High Fire Hazard Severity Zones to submit fire protection plan. This plan shall be approved by both the fire code official and the authorized representative for the local CAL FIRE Unit Chief (if located in the State Responsibility Area [SRA]) prior to the recording of the final map for the project by the County of El Dorado.~~

Section 4905 Wildfire Protection Building Construction

~~4905.4 Roof Construction Requirements shall be added as follows: All new construction, including additions, requires a Class A roof covering or assembly. All re-roofing requires Class A roof covering or assembly as a minimum. Re-roofing in excess of 50% of an existing structure within any one year period will necessitate that the entire roof be a Class A roof covering or assembly as a minimum. Class B or C fire retardant treated and or non-treated wood shake or shingles are not approved as a roof covering material for Class A assembly.~~

Chapter 50

SECTION 5001.7 "LIABILITY FOR DAMAGES" SHALL BE ADDED AS FOLLOWS:

Section 5001.7 Liability for Damages. Any damages or cost resulting from the negligence, violation of the law, careless handling, spill or discharge of any hazardous materials shall ~~constitute~~ constitute debt against any such person, firm or corporation causing such spill or discharge. This debt is collectible by the Fire Chief, or his/her duly authorized representative, in the same manner as in the case of an obligation under contract, expressed or implied.

Chapter 56

SECTION 5601.2 "PERMIT REQUIRED" SHALL BE AMENDED AS FOLLOWS:

Section 5601.2 Permit Required. Permits shall be required as set forth in Section 105.56 and regulated in accordance with this section. ~~Where explosives permits are required, they shall be issued by the Fire Chief, or his/her duly authorized representative, and the El Dorado County Sheriff's Department. Where fireworks permits are required, they shall be issued by the Fire Chief, or his/her duly authorized representative, and the El Dorado County Board of Supervisors.~~

~~5601.2.1 DOCUMENTATION SHALL BE ADDED AS FOLLOWS:~~

~~The AHJ shall have the authority to request documentation regarding all aspects of the fireworks presentation.~~

~~5601.2.2 PROPRIETARY INFORMATION SHALL BE ADDED AS FOLLOWS:~~

~~The AHJ will protect all proprietary information.~~

Chapter 57

SECTION 5704.2.9.6.1 "LOCATIONS WHERE ABOVE-GROUND TANKS ARE PROHIBITED" SHALL BE AMENDED AS FOLLOWS:

SECTION 5704.2.9.6.1 Locations Where Above-Ground Tanks are Prohibited. Storage of Class I and Class II flammable liquids in above-ground tanks outside of buildings is prohibited within the limits established by law as the limits of districts in which such storage is prohibited. Storage of Class I and Class II flammable liquids in above-ground tanks outside of buildings is prohibited unless approved by the fire code official ~~Fire Chief, or his/her duly authorized~~

~~representative. When permitted by the Fire Chief, or his/her duly authorized representative, all above-ground tank(s) or vault installations for the storage of Class I, II or III flammable and combustible liquids shall comply with those requirements as set forth by the California Fire Code. The California Fire Code shall also apply to installations other than motor vehicle fuel dispensing stations where above-ground storage is required.~~

SECTION 5706.2.4.4 "LOCATIONS WHERE ABOVE-GROUND TANKS ARE PROHIBITED" SHALL BE AMENDED AS FOLLOWS:

SECTION 5706.2.4.4 Locations Where Above-Ground Tanks are Prohibited. The storage of Class I and Class II liquids in above-ground tanks is prohibited within the limits established by law as the limits of districts in which such storage is prohibited. ~~Storage of Class I and Class II liquids in above-ground tanks is prohibited unless approved by the fire code officialthe Fire Chief, or his/her duly authorized representative. When permitted by the Fire Chief, or his/her duly authorized representative, all above-ground tank(s) or vault installations for the storage of Class I, II or III flammable and combustible liquids shall comply with those requirements as set forth by the California Fire Code. The California Fire Code shall also apply to installations other than motor vehicle fuel dispensing stations where above-ground storage is required.~~

Chapter 58

SECTION 5806.2 "LIMITATIONS" SHALL BE AMENDED AS FOLLOWS:

SECTION 5806.2 Limitations. Storage of flammable cryogenic fluids in stationary containers outside of buildings is prohibited within the limits established by law as the limits of districts in which such storage is prohibited. ~~Storage of flammable cryogenic fluids in stationary containers outside of buildings is prohibited unless approved by the fire code officialFire Chief, or his/her duly authorized representative. When permitted by the Fire Chief, or his/her duly authorized representative, all stationary containers for the storage of flammable cryogenic fluids shall comply with those requirements as set forth by the California Fire Code. The California Fire Code shall also apply to installations other than motor vehicle fuel dispensing stations where above-ground storage is required.~~

Chapter 61

SECTION 6104.2 "MAXIMUM CAPACITY WITHIN ESTABLISHED LIMITS" SHALL BE AMENDED AS FOLLOWS:

SECTION 6104.2 Maximum Capacity within Established Limits. Within the limits established by law restricting the storage of liquefied petroleum gas for the protection of heavily populated or congested areas, the aggregate capacity of any one installation shall not exceed a water capacity of 2,000 gallons. ~~The storage of liquefied petroleum gas in excess of an aggregate of 2,000-gallon water capacity when located at least one-half (1/2) mile from property zoned or designated for residential use and at least one-half (1/2) mile from existing residential development with a density greater than one (1) dwelling unit per acre and at least one-half (1/2) mile from any hotel or motel is allowed when AHJ-approved by the fire code official, and a special/conditional use permit is issued by the County of El Dorado.~~

Dispensing within established limits. Within the limits established by law restricting the ~~dispensing dispersion~~ of liquefied petroleum gas for the protection of heavily populated or congested areas, the aggregate capacity of any one installation shall not exceed a water capacity of 2,000 gallons. The dispensing of liquefied petroleum gas in excess of an aggregate of 2,000-gallon water capacity when located at least one-half (1/2) mile from property zoned or designated for residential use ~~and at least one-half (1/2) mile from existing residential development with a density greater than one (1) dwelling unit per acre~~ and at least one-half (1/2) mile from any hotel or motel is allowed when ~~AHJ~~ approved by the fire code official and a special/conditional use permit is issued by the County of El Dorado.

~~SECTION 6113.1 PERMITS AND PLANS SHALL BE ADDED AS FOLLOWS:~~

~~Permits shall be required, and plans shall be submitted for all underground tank installations as approved by the AHJ.~~

~~SECTION 6113.2 UNDERGROUND LPG TANK OWNERSHIP SHALL BE ADDED AS FOLLOWS:~~

~~Underground LPG tanks shall be prohibited from being sold to end users and shall be retained by the LPG company under a lease-type system to ensure proper annual maintenance requirements are met and recorded.~~

Chapter 80

SECTION 80, NFPA 1-22, CHAPTER 22 "AUTOMOTIVE WRECKING YARDS" IS ADOPTED, AMENDED SECTIONS AS FOLLOWS:

Revise Section 22.3 as follows:

22.3 Fire department access roads shall be in accordance with ~~Section 18.2~~ the California Fire Code, Section 503 and Appendix D.

Add new Section 22.10 as follows:

22.10 Stored vehicles, boats, recreational vehicles, parts, and equipment shall not be stored within 30 feet of adjacent property lines.

SECTION 80, NFPA, 13D-~~16-22~~ – "STANDARD FOR THE INSTALLATION OF SPRINKLER SYSTEMS IN ONE-AND TWO FAMILY DWELLINGS AND MANUFACTURED HOMES" IS AMENDED AS FOLLOWS: 903.3.1.3, 903.3.5.1.1

NFPA 13D, Amended Sections as follows:

Add new Section 4.~~7-6 to read~~ as follows:

4.~~7-6~~ Residential fire sprinkler systems installed in all new one-and two-family dwellings shall utilize a "Passive Purge" system design unless otherwise approved by the fire code official.

Exception: *Manufactured home installed, tested and approved by the California Department of Housing and Community Development.*

Formatted: Font: Not Bold

Formatted: Strikethrough

Revise Section 5.1.1.2 ~~to read~~ as follows:

5.1.1.2 A supply of at least one of each type and temperature sprinkler used within the premises shall be maintained on the property at an approved location. ~~Spare Steek~~ sprinklers shall be kept in a mounted and accessible cabinet.

Revise Section 7.6 ~~to read~~ as follows:

7.6 A local audio/visual device activated upon water flow ~~alarm~~ shall be provided on all fire sprinkler systems in homes at an approved location on the exterior of the dwelling.

Revise Section 11.2.1.1 ~~to read~~ as follows:

11.2.1.1 Where a fire department pumper connection is not provided, the system shall be hydrostatically tested at a minimum pressure of 150 pounds per square inch gauge for no less than a 30-minute duration without evidence of leakage. Such test shall be witnessed by the fire code official.

Appendix B – Fire Flow Requirements for Buildings

TABLE B105.1(1) "REQUIRED FIRE FLOW FOR ONE- AND TWO-FAMILY DWELLINGS, GROUP R-3, AND R-4 BUILDINGS AND TOWNHOUSES" SHALL BE AMENDED AS FOLLOWS:

TABLE B105.1(1) REQUIRED FIRE FLOW FOR ONE- AND TWO-FAMILY DWELLINGS, GROUP R-3, AND R-4 BUILDINGS AND TOWNHOUSES

FIRE-FLOW CALCULATION AREA (square feet)	AUTOMATIC SPRINKLER SYSTEM (Design Standard)	MINIMUM FIRE-FLOW (gallons per minute)	FLOW DURATION (hours)
0 – 3,600	No automatic sprinkler system	1,000	1
3,601 and greater	No automatic sprinkler system	Value in Table B105.1(2)	Duration in Table B105.1(2) at the required fire-flow rate
<u>MAJOR SUBDIVISIONS (5 PARCELS OR GREATER)</u>			
0 – 3,600	Section 903.3.1.3 of the CA Fire Code or Section 313.3 of the CA Residential Code	500 <u>1,000</u>	½ <u>1</u>

3,601 and greater	Section 903.3.1.3 of the CA Fire Code or Section 313.3 of the CA Residential Code	1/2 value of Table B105.1(2) (<u>min. 1000 GPM</u>)	4 <u>2</u>
<u>OTHER RESIDENTIAL DEVELOPMENT</u>			
0 – 3,600	Section 903.3.1.3 of the CA Fire Code or Section 313.3 of the CA Residential Code	500	1/2 <u>1</u>
3,601 and greater	Section 903.3.1.3 of the CA Fire Code or Section 313.3 of the CA Residential Code	1/2 value of Table B105.1(2) (<u>min. 750 GPM</u>)	1

TABLE B105.2 "REQUIRED FIRE FLOW FOR BUILDINGS OTHER THAN ONE- AND TWO-FAMILY DWELLINGS, GROUP R-3, AND R-4 BUILDINGS AND TOWNHOUSES" SHALL BE AMENDED AS FOLLOWS:

TABLE B105.2 REQUIRED FIRE FLOW FOR BUILDINGS OTHER THAN ONE- AND TWO-FAMILY DWELLINGS, GROUP R-3, AND R-4 BUILDINGS AND TOWNHOUSES

AUTOMATIC SPRINKLER SYSTEM (Design Standard)	MINIMUM FIRE-FLOW (gallons per minute)	FLOW DURATION (hours)
No automatic sprinkler system	Value in Table B105.1(2)	Duration in Table B105.1(2)
Section 903.3.1.1 of the CA Fire Code	25% of the value in Table B105.1(2) ^b	Duration in Table B105.1(2) at the reduced flow rate
Section 903.3.1.2 of the CA Fire Code	25%-50% of the value in Table B105.1(2)	Duration in Table B105.1(2) at the reduced flow rate

~~a. The reduced fire flow shall not be less than 1,000 gpm~~

b. The reduced fire flow shall not be less than 1,500 gpm

Appendix D – Fire Apparatus Access Roads

SECTION D103.1 "ACCESS ROAD WIDTH WITH A HYDRANT" SHALL BE AMENDED AS FOLLOWS:

Section D103.1 Access Road Width with a Hydrant. Where a fire hydrant is located on a fire apparatus access road, the minimum road width shall be 26 feet (7925 mm), exclusive of shoulders (see Figure D103.1).

Exception: Driveways

SECTION D103.2 "GRADE" SHALL BE AMENDED AS FOLLOWS:

SECTION D103.2 Grade. Fire apparatus access roads *and driveways* shall not exceed ~~10~~ 15.9% in grade unless approved by the fire code official AHJ or by the El Dorado County amended California Public Resource Code Title 14 / Design and Improvement Standards Manual.

SECTION D103.3 "TURNING RADIUS" SHALL BE AMENDED AS FOLLOWS:

SECTION D103.3 Turning Radius. The minimum turning radius shall be determined by the fire code official; *and shall not include curb and gutter.*

SECTION D103.5 "FIRE APPARATUS ACCESS ROAD GATES" SHALL BE AMENDED AS FOLLOWS:

SECTION D103.5 Fire Apparatus Access Road Gates. Gates securing the fire apparatus access roads shall comply with all of the following criteria:

1. Where a single gate is provided, the gate width shall be not less than 20 feet (6096 mm). Where a fire apparatus road consists of a divided roadway, the gate width shall be not less than ~~15+2~~ feet (3658 mm).
2. Gates shall be of the horizontal swing, horizontal slide, vertical lift or vertical pivot type.
3. Construction of gates shall be of materials that allow manual operation by one person.
4. Gate components shall be maintained in an operative condition at all times and replaced or repaired when defective.
5. Electric gates shall be equipped with a means of opening the gate by fire department personnel for emergency access. Emergency opening devices shall be approved by the fire code official.
6. Methods of locking shall be submitted for approval by the fire code official.
7. Electric gate operators, where provided, shall be listed in accordance with UL 325.
8. Gates intended for automatic operation shall be designed, constructed and installed to comply with the requirements of ASTM F2200.

SECTION D103.6.1 "ROADS 20 TO ~~26~~29 FEET IN WIDTH" SHALL BE AMENDED AS FOLLOWS:

SECTION D103.6.1 Roads 20 to 2629 feet in width. Fire lane signs as specified in Section D103.6 shall be posted on both side of fire apparatus access roads that are 20 to ~~26~~29 feet wide (6096 to ~~7925~~8534.4 mm).

SECTION D103.6.2 "ROADS MORE THAN ~~26~~29 FEET IN WIDTH" SHALL BE AMENDED AS FOLLOWS:

SECTION D103.6.2 Roads more than ~~26~~29 feet in Width. Fire lane signs as specified in Section D103.6 shall be posted on one side of fire apparatus access roads more than ~~26~~29 feet wide (8534.4 mm) and less than ~~32~~36 feet wide (~~9754~~10972.8 mm).

SECTION D104.4 "CIRCUMFERENTIAL FIRE APPARATUS ACCESS ROADS" SHALL BE ADDED AS FOLLOWS:

SECTION D104.4 Circumferential Fire Apparatus Access Roads. *When required by the fire code official, a fire apparatus access road shall be constructed to encompass the entirety of a structure and shall provide a continuous means of emergency vehicle access.*

SECTION 4: CONFLICT

That Ordinance No. ~~2016~~2019-37-01 of the RFPD, and all other ordinances or parts of ordinances herewith are hereby repealed.

SECTION 5: SEVERABILITY

If any Ordinance, article, subsection or subdivision thereof, provision, sentence, clause or phrase of this code, or any application thereof, is for any reason held to be invalid by a court of competent jurisdiction, such decision shall not affect the remaining provisions of this code, which can be given effect without the invalid portions and, therefore, such invalid portions are declared to be severable. The RFPD hereby declares that it would have enacted this Ordinance and each of its articles, sections, subsections, or subdivisions thereof, provisions, sentences, clauses or phrases irrespective of the fact that one or more of them is declared invalid.

SECTION 6: EFFECTIVE DATE AND PUBLICATION

This Ordinance shall take effect thirty (30) days after its adoption. The RFPD Board Secretary is directed to publish this ordinance in a newspaper of general circulation in the District. In lieu of publication of the full text of the ordinance, a summary of the ordinance may be published by the by the Board Secretary within fifteen (15) days after its passage and a certified copy shall be posted in the office of the RFPD pursuant to *Government Code Section 36933(c) (1)*.

The above Ordinance was introduced at a meeting of the Board of Directors of the RFPD on ~~October~~ September 14~~7~~, 20~~22~~19, and it was then read for the first time. A public hearing was set for the Ordinance to be read for the second time on ~~November~~ October 12~~4~~, 20~~22~~19 and approved by the following vote:

PASSED AND ADOPTED by the Board of Directors of the Rescue Fire Department this,
_____ day of _____, 202219.

AYES:

NOES:

ABSENT:

ABSTAIN:

XXXX, Board President

ATTEST:

Aja Mercado, Board Secretary

RESCUE FIRE DEPARTMENT

ORDINANCE NO. 2022-01

BE IT ORDAINED BY THE BOARD OF DIRECTORS OF THE RESCUE FIRE DEPARTMENT AS FOLLOWS:

An ordinance of the Rescue Fire Protection District (RFPD) adopting the 2022 Edition of the *California Fire Code*, incorporating the 2021 Edition of the *International Fire Code*, regulating and governing the safeguarding of life and property from fire and explosion hazards arising from the storage, handling and use of hazardous substances, materials and devices, and from conditions hazardous to life or property in the occupancy of buildings and premises in the Rescue Fire Department; providing for the issuance of permits and collection of fees therefor; Repealing Ordinance No. 2019-01 of the RFPD and all other ordinances and parts of the ordinances in conflict therewith.

Be it ORDAINED by the Board of Directors of the RFPD:

Section 1: **FINDINGS OF FACTS**

Section 2: **ADOPTION OF CODE WITH EXCLUSIONS**

Section 3: **LOCAL AMENDMENTS**

Section 4: **CONFLICT**

Section 5: **SEVERABILITY**

Section 6: **EFFECTIVE DATE AND PUBLICATION**

SECTION 1: FINDINGS OF FACTS

The Rescue Fire Department makes certain changes (listed below) to the *California Fire Code*, 2022 Edition, pursuant to *Health & Safety Code Sections 13869.7, 17958.5, 17958.7 and 18941.5* during this code adoption process. Such changes are necessary because of local climatic, geological and/or topographical conditions. The RFPD has adopted, pursuant to *Section 18941.5* of the *California Health & Safety Code*, the findings of facts relative to these conditions by Resolution #2022-10 of the RFPD dated October 12, 2022.

SECTION 2: ADOPTION OF CODE WITH EXCLUSIONS

The RFPD adopts the 2022 *California Fire Code, Title 24, Part 9, in its entirety*, including Appendices, incorporating those sections of the *International Fire Code, 2021* edition not adopted by the state, with the exclusions listed below:

Exclusions: 103, 309, 311.5, 311.6, 318, 403.3, 403.5, 403.8, 403.10, 403.11, 404, 406, 903.3.1.2, 904.1.1, 1103.1, 1103.3-1103.4, 1103.6, 1105, Chapter 26, D104.2 (Exception only), D106.1 (Exception only), D107.1 (Exceptions only), Appendix A, Appendix G, Appendix J, Appendix K, Appendix L, Appendix M, Appendix N, Appendix O.

Appendices not adopted can be used for reference in enforcing other sections of the 2022 *California Fire Code*.

SECTION 3: AMENDMENTS TO THE 2022 CALIFORNIA FIRE CODE

The following Sections are hereby amended or added:

Chapter 1

SECTION 101.1 "TITLE" SHALL BE AMENDED AS FOLLOWS:

Section 101.1 TITLE. These regulations shall be known as the Fire Code of RFPD, hereinafter referred to as "this code".

SECTION 105.5 "REQUIRED OPERATIONAL PERMITS" IS AMENDED AS FOLLOWS:

Section 105.5 Required operational permits. The fire code official is authorized to issue operational permits for the operations set forth in Sections 105.5.2 through 105.5.525.

SECTION 105.5.55 "AUTOMOBILE WRECKING YARDS" IS ADDED AS FOLLOWS:

Section 105.5.55 Automobile wrecking yards. *An operational permit is required for the operation of automobile wrecking yards.*

SECTION 105.6 "REQUIRED CONSTRUCTION PERMITS" IS AMENDED AS FOLLOWS:

Section 105.6 required construction permits. The fire code official is authorized to issue construction permits for work as set forth in sections 105.6.1 through 105.6.246.

SECTION 105.6.25 "AUTOMOBILE WRECKING YARDS" IS ADDED AS FOLLOWS:

Section 105.6.25 Automobile wrecking yards. *Construction permits are required for the installation of or modification to automobile wrecking yards.*

SECTION 105.6.26 "TRAFFIC CALMING DEVICES" IS ADDED AS FOLLOWS:

105.6.26 Traffic calming devices. Construction permits are required for the installation or modification of traffic calming devices.

SECTION 107.5 "PERMIT, PLAN REVIEW AND INSPECTION FEES" SHALL BE ADDED AS FOLLOWS:

Section 107.5 Permit. A schedule of fees adopted by the district board of directors for plan review, inspections and the issuance of permits by the district may be found in the most current district fee schedule (Health & Safety Code 17951).

SECTION 107.5.1 "COST RECOVERY FEES" SHALL BE ADDED AS FOLLOWS:

Section 107.5.1 Cost Recovery Fees. Fire service fees may be charged to any person, firm, corporation or business that through negligence, violation of the law, or as a result of carelessness, is responsible for the cause of the district to respond to the scene of an incident. A district board may charge a fee to cover the cost of any service which the district provides or the cost of enforcing any regulation for which the fee is charged (Health & Safety Code 13916). The fee shall not exceed the actual cost of suppressing the fire and/or responding to the scene of an incident.

SECTION 107.7 "ADMINISTRATIVE COSTS" SHALL BE ADDED AS FOLLOWS:

Section 107.7 Administrative Costs. When a test or inspection is scheduled, and the contractor fails to perform to the satisfaction of the authority having jurisdiction (AHJ), the AHJ may bill the contractor for actual time spent traveling to and from the test/inspection location and the time spent at the test/inspection site as well as administrative costs.

SECTION 111.5 "APPEAL PROCEDURES AND TIMELINES" SHALL BE ADDED AS FOLLOWS:

Section 111.5 Appeal Procedures and Timelines. Any person or entity who believes they may be adversely affected by an order, decision, or determination made by the fire code official through a written notice may appeal this matter within 15 calendar days of the postmark on the notice. All such appeals shall be filed in writing with the Secretary of the Governing Board for the district. A timely appeal shall stay further action by the fire code official until the matter is determined by the Appeal Board as outlined in Section 109.2, unless the issue poses an imminent fire or life safety hazard to members of the public. The fire code official shall notify the appellant by certified mail of the date and time of such hearing. The hearing shall be scheduled to take place no sooner than 20 calendar days from the date shown on the certified mail. The appellant shall have the right to appear in person or by agent at the hearing and present oral, written and/or photographic evidence to the Appeal Board.

SECTION 112.4 "VIOLATION PENALTIES" SHALL BE AMENDED AS FOLLOWS:

Section 112.4 Violation Penalties. Persons who shall violate a provision of this code or shall fail to comply with any of the requirements thereof or who shall erect, install, alter, repair or do work in violation of the approved construction documents or directive of the fire code official, or of a permit or certificate used under provisions of this code, shall be guilty of a *misdemeanor or infraction*, at the discretion of the prosecuting attorney or agency, punishable by a fine not more than \$100.00 for a first violation; A fine not exceeding \$500.00 for a second violation of

the same provision within one year; A fine not exceeding \$1000.00 for each additional violation of the same provision within one year, or by imprisonment not exceeding 180 days, or both such fine and imprisonment. Each day that a violation continues after due notice has been served shall be deemed a separate offense. (Health & Safety Code Sections 13145 and 17995).

SECTION 112.4.2 "CITATIONS" SHALL BE ADDED AS FOLLOWS:

Section 112.4.2 Citations. *The Fire Chief, or his/her duly authorized representative, may issue citations for infractions or misdemeanor violations of this code pursuant to Section 13871 of the Health & Safety Code of the State of California and Chapter 5c (commencing with Section 853.6) of Title 3 of Part 2 of the Penal Code of the State of California.*

SECTION 113.4 "FAILURE TO COMPLY" SHALL BE AMENDED AS FOLLOWS:

Section 113.4 Failure to Comply. *Any person who shall continue any work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be punishable by a fine or imprisonment or both as described in Section 112.4 (Health & Safety Code Sections 13145 and 17995).*

Chapter 2

SECTION 202 "CAMPFIRE" SHALL BE ADDED AS FOLLOWS:

CAMPFIRE. *A fire which is used for cooking, personal warmth, lighting, or aesthetic purposes.*

SECTION 202 "DISTRICT" SHALL BE ADDED AS FOLLOWS:

DISTRICT. *The district and all other areas within the exterior boundaries thereof now or hereafter established.*

SECTION 202 "DRIVEWAY" SHALL BE ADDED AS FOLLOWS:

DRIVEWAY. *A vehicular access that serves up to two (2) parcels with no more than two (2) residential units and any number of non-commercial or industrial buildings on each parcel.*

SECTION 202 "EXECUTIVE BODY" SHALL BE ADDED AS FOLLOWS:

EXECUTIVE BODY. *The Board of Directors of the District.*

SECTION 202 "FIRE CHIEF" SHALL BE ADDED AS FOLLOWS:

FIRE CHIEF. *The Chief Executive Fire Officer of the Fire department/district serving the jurisdiction or a duly authorized representative.*

SECTION 202 "FIRE HAZARD" SHALL BE ADDED AS FOLLOWS:

FIRE HAZARD. *Any condition, arrangement, or act which will increase, or may cause an increase of, the hazard or menace of fire to a greater than customarily recognized as normal*

by-persons in the public service of preventing, suppressing or extinguishing fire; or which may obstruct, delay, or hinder, or may become the cause of obstruction, delay or hinderance to the prevention, suppression, or extinguishment of fire.

SECTION 202 "OPEN BURNING" SHALL BE AMENDED AS FOLLOWS:

OPEN BURNING. The burning of materials wherein products of combustion are emitted directly into the ambient air without passing through a stack or chimney from an enclosed chamber. Open burning does not include road flares, smudge-pots and similar devices associated with safety or occupational uses typically considered open flames. For the purpose of this definition, a chamber shall be regarded as enclosed when, during the time combustion occurs, only apertures, ducts, stacks, flues or chimneys necessary to provide combustion air and permit the escape of exhaust gas are open.

Open burning shall also include campfires, bonfires, portable outdoor fireplaces, ceremonial fires, and recreational fire as defined in the Fire Code.

Exception:

1. *UL or ASMI listed LPG or natural gas outdoor flame devices, such as gas BBQ's or gas fire pits that comply with the Fire Code.*
2. *For one-or two-family dwellings, fixed or portable outdoor flame devices that meet the following:*
 - a. *Devices shall comply with the Fire Code.*
 - b. *Devices shall be used per manufacturer's specifications.*
 - c. *Minimum 10-foot clearance from device to all flammable material and vegetation.*
 - d. *No burning shall be conducted during high or extreme fire weather conditions (e.g., National Weather Service Red Flag Warnings).*
3. *Campfires on private lands. Where required by the fire code official, a permit shall be issued by the fire code official.*
4. *Ceremonial and/or religious burning with the following safety measures:*
 - a. *Maximum 4-foot x 4-foot burn area.*
 - b. *Minimum 10-foot clearance from edge of burn area to all flammable material and vegetation.*
 - c. *An approved water supply is located within 500-feet of the burn area.*
 - d. *The burn area is located no less than 30-feet from adjoining property lines.*
 - e. *An adult is present with a shovel until the fire is extinguished.*
 - f. *No burning shall be conducted during high or extreme fire weather conditions (e.g., National Weather Service Red Flag Warnings).*

SECTION 202 "TRAINED CROWD MANAGER" SHALL BE ADDED AS FOLLOWS:

TRAINED CROWD MANAGER. *Standby personnel, usually a security guard or usher personnel, who are trained in the proper procedure to exit people from a tent or other place of public assemblage in an orderly and calm fashion in the event of an emergency*

Chapter 3

SECTION 302.1 “DEFINITIONS” SHALL BE AMENDED AS FOLLOWS:

3D PRINTER.

ADDITIVE MANUFACTURING.

BONFIRE.

CAMPFIRE.

HI-BOY.

HIGH-VOLTAGE TRANSMISSION LINE.

OPEN BURNING.

PORTABLE OUTDOOR FIREPLACE.

POWERED INDUSTRIAL TRUCK.

RECREATIONAL FIRE.

SKY LATTERN.

SECTION 307.4.4 “OPEN BURNING RESTRICTIONS” SHALL BE ADDED AS FOLLOWS:

Section 307.4.4 Open Burning Restrictions. *Open burning on all lands within the jurisdiction of the Rescue Fire Department, including the Local Response Area (LRA), is prohibited when the California Department of Forestry and Fire Protection (Cal Fire) issues a burn suspension in the State Responsibility Area (SRA). This prohibition shall be made effective 24-hours following its commencement in the SRA.*

Open burning is also prohibited on all lands within the jurisdiction of Rescue Fire Department at any time the fire code official that atmospheric conditions or other local circumstances make such fires hazardous, including factors such as high winds, low fuel moisture, fire weather, the issuance of red flag warnings, severe threat of wildland fire, or present risk of destruction by wildfire to life, wildlife, property, or natural resources.

Chapter 4

SECTION 401.2.1 “PRE-FIRE PLANS” IS ADDED AS FOLLOWS:

Section 401.2.1 Pre-fire plans. *Where required by the fire code official, a pre-fire plan shall be provided and approved by the fire code official for all new commercial structures.*

Chapter 5

SECTION 503.2.1 “DIMENSIONS” SHALL BE AMENDED AS FOLLOWS:

Section 503.2.1 Dimensions. *Fire apparatus access roads shall have an unobstructed width of not less than 20 feet (6096 mm), exclusive of shoulders, as measured from face of curb to face of curb, except for approved security gates in accordance with Section 503.6, and an*

unobstructed vertical clearance of not less than 15 feet. *Driveways shall have an unobstructed width of not less than 12 feet wide.*

SECTION 503.2.5 “DEAD ENDS” SHALL BE AMENDED AS FOLLOWS:

Section 503.2.5 Dead Ends. Dead-end fire apparatus access roads *and driveways* in excess of 150 feet (45,720 mm) in length shall be provided with an approved area for turning around fire apparatus.

SECTION 503.2.6 “BRIDGES AND ELEVATED SURFACES” SHALL BE AMENDED AS FOLLOWS:

Section 503.2.6 Bridges and Elevated Surfaces. Where a bridge or an elevated surface is part of a fire apparatus access road, the bridge shall be constructed and maintained in accordance with AASHTO HB-17, *the current El Dorado County Transportation Division Bridge Standard or Appendix D of the current California Fire Code, whichever is more restrictive.* Bridges and elevated surfaces shall be designed for a live load sufficient to carry the imposed loads of fire apparatus. Vehicle load limits shall be posted at both entrances to bridges when required by the fire code official. Where elevated surfaces designed for emergency vehicle use are adjacent to surfaces that are not designed for such use, approved barriers, approved signs or both shall be installed and maintained where required by the fire code official.

SECTION 503.3.1 “NO PARKING IN FIRE LANES” SHALL BE ADDED AS FOLLOWS:

Section 503.3.1 No Parking In Fire Lanes. *No person shall stop, park, or leave standing any vehicle, whether attended or unattended, except when necessary to avoid conflict with other traffic or in compliance with the directions of the Fire Chief, or his/her duly authorized representative, Peace Officer or official traffic control device along the edge of any highway, at any curb, or in any location in a publicly or privately owned or operated off-street parking facility, designated as a fire lane by the district with jurisdiction over the area in which the place is located. The designation shall be indicated (1) by a sign posted immediately adjacent to, and visible from, the designated place clearly stating in letters not less than one inch in height that the place is a fire lane, (2) by outlining or painting the place in red and, in contrasting color, marking the place with the words “FIRE LANE”, which are clearly visible from a vehicle, or (3) by a red curb or red paint on the edge of the roadway upon which is clearly marked the words “FIRE LANE”.*

SECTION 503.3.2 “NO PARKING IN FRONT OF HYDRANTS” SHALL BE ADDED AS FOLLOWS:

Section 503.3.2 No Parking in Front of Hydrants. *No person shall stop, park, or leave standing any vehicle within 15 feet of a fire hydrant except as follows: (a) If the vehicle is attended by a licensed driver who is seated in the front seat and who can immediately move such vehicle in case of necessity, (b) If the vehicle is owned or operated by a fire department and is clearly marked as a fire department vehicle.*

SECTION 503.3.3 “FIRE LANES BASED ON ROAD WIDTH” SHALL BE ADDED AS FOLLOWS:

Section 503.3.3 Fire Lanes Based on Road Width. *Fire lanes shall be based on road width as required in Appendix D as amended by the District.*

SECTION 503.6 "SECURITY GATES" IS AMENDED AS FOLLOWS:

Section 503.6 Security Gates. The installation of security gates across a fire apparatus access road shall be approved by the fire code official *and shall comply with the District gate standard.* Where security gates are installed, they shall have an approved means of emergency operation. The security gates and the emergency operation shall be maintained operational at all times. Electric gate operators, where provided, shall be listed in accordance with UL 325. Gates intended for automatic operation shall be designed, constructed, and installed to comply with the requirements of ASTM F2200.

SECTION 505.1 "ADDRESS IDENTIFICATION" SHALL BE AMENDED AS FOLLOWS:

Section 505.1 Address Identification. *Addresses for new and existing buildings shall comply with the District address standard as approved by the fire code official.* The address identification shall be legible and placed in a position that is visible from the street or road fronting the property. Address identification characters shall contrast with their background. Address numbers shall be Arabic numbers or alphabetical letters. Numbers shall not be spelled out. Each character shall be not less than 4 inches (102 mm) high with a minimum stroke width of 1/2 inch (12.7 mm). Where required by the fire code official, address identification shall be provided in additional approved locations to facilitate emergency response. *access is by means of a private road and the building cannot be viewed from the public way, a monument, pole or other sign or means shall be used to identify the structure.* Address identification shall be maintained.

SECTION 507.5.1 "WHERE REQUIRED" SHALL BE AMENDED AS FOLLOWS:

Section 507.5.1 Where Required. Where a portion of the facility or building hereafter constructed or moved into or within the jurisdiction is more than 150 feet from a hydrant on a fire apparatus access road, as measured by an approved route around the exterior of the facility or building, on-site fire hydrants and mains capable of supplying the required fire flow shall be provided where required by the fire code official.

Exceptions:

1. For Group R-3 and Group U occupancies, the distance requirement shall be 600 feet (183 m).

SECTION 509.3 "FIRE CONTROL ROOM" SHALL BE ADDED AS FOLLOWS:

Section 509.3 Fire Control Room. *Fire sprinkler risers, fire alarm control panels, solar photovoltaic power system rapid shutoff switches, and other fire detection, suppression or similar control elements shall be located inside a single fire control room for the building. The fire control room shall have minimum dimensions of five feet by seven feet in size with a total usable area of not less than 35 square feet. The room shall be located within the building on an outside wall at a location approved by the Fire Code Official and shall be accessible from the exterior. An exterior access door with a clear width of not less than 32 inches and height of not less than 80 inches shall be provided for access into the room. A durable sign shall be affixed to the exterior of the door with the words "FIRE CONTROL ROOM" in letters not less*

than 4 inches in height. A key box complying with Section 506 shall be installed on the exterior side of the fire control room door opening.

The room must be capable of maintaining a minimum temperature of 40 degrees Fahrenheit. A clearance of 12 inches shall be provided from the fire sprinkler risers to any adjacent walls. This room can be a shared with other building utilities or fire protection equipment that is not incompatible. An approved cabinet or container shall be provided to store record plans of the fire sprinkler system and other fire protection equipment. This room shall not be used for any other storage.

Exception: One-and two-family dwellings, manufactured homes or similar uses defined as either a Group R-3, R3.1, or R-4 occupancy.

SECTION 510.4.2.3 "STANDBY POWER" SHALL BE AMENDED AS FOLLOWS:

Section 510.4.2.3 Standby power. In-building, two-way emergency responder communication radio coverage systems shall be provided with dedicated standby batteries or provided with 2-hour standby batteries and connected to the facility generator power system in accordance with Section 1203. The standby power supply shall be capable of operating the in-building, two-way emergency responder communication coverage system at 100-percent system capacity for a duration of not less than 72 hours.

Chapter 9

SECTION 903.2 "WHERE REQUIRED" SHALL BE AMENDED AS FOLLOWS:

Section 903.2 Where Required. Approved automatic sprinkler systems *in new buildings and structures when constructed or relocated within the jurisdiction shall be provided in the locations* described in Sections 903.2.1 through 903.2.12 and Sections 903.2.14 through 903.2.23.

Exception: *Agricultural buildings not under a special use permit used for commercial purposes.*

SECTION 903.2.1.1 "GROUP A-1" SHALL BE AMENDED AS FOLLOWS:

Section 903.2.1.1 Group A. An automatic sprinkler system shall be provided throughout stories containing Group A-1 occupancies and throughout all stories from the Group A-1 occupancy to and including the levels of exit discharge serving that occupancy where one of the following conditions exists:

1. The fire area exceeds 3,600 square feet.
2. The fire area has an occupant load of 300 or more.
3. The fire area is located on a floor other than a level of exit discharge serving such occupancies.
4. The fire area contains a multi-theater complex

SECTION 903.2.1.2 "GROUP A-2" SHALL BE AMENDED AS FOLLOWS:

Section 903.2.1.2 Group A-2. An automatic sprinkler system shall be provided throughout stories containing Group A-2 occupancies and throughout all stories from the Group A-2

occupancy to and including the levels of exit discharge serving that occupancy where one of the following conditions exists:

1. The fire area exceeds 3,600 square feet;
2. The fire area has an occupant load of 100 or more.
3. The fire area is located on a floor other than a level of exit discharge serving such occupancies.
4. The structure exceeds 3,600 square feet, contains more than one fire area containing a Group A-2 occupancy, and is separated into two or more buildings by fire walls of less than 4-hour fire-resistance rating without openings.

SECTION 903.2.1.3 "GROUP A-3" SHALL BE AMENDED AS FOLLOWS:

Section 903.2.1.3 Group A-3. An automatic sprinkler system shall be provided throughout stories containing Group A-3 occupancies and throughout all stories from the Group A-3 occupancy to and including the levels of exit discharge serving that occupancy where one of the following conditions exists:

1. The fire area exceeds 3,600 square feet.
2. The fire area has an occupant load of 300 or more.
3. The fire area is located on a floor other than a level of exit discharge serving such occupancies.
4. The structure exceeds 3,600 square feet, contains more than one fire area containing exhibition and display rooms, and is separated into two or more buildings by fire walls of less than 4-hour fire-resistance rating without openings.

SECTION 903.2.1.4 "GROUP A-4" SHALL BE AMENDED AS FOLLOWS:

Section 903.2.1.4 Group A-4. An automatic sprinkler system shall be provided throughout stories containing Group A-4 occupancies and throughout all stories from the Group A-4 occupancy to and including the levels of exit discharge serving that occupancy where one of the following conditions exists:

1. The fire area exceeds 3,600 square feet.
2. The fire area has an occupant load of 300 or more.
3. The fire area is located on a floor other than a level of exit discharge serving such occupancies.

SECTION 903.2.3 "GROUP E" SHALL BE AMENDED AS FOLLOWS:

Section 903.2.3 Group E. An automatic sprinkler system shall be provided for Group E occupancies as follows:

1. Throughout all Group E fire areas greater than 3,600 square feet in area.
2. The Group E fire area is located on a floor other than a level of exit discharge serving such occupancies.

Exception: In buildings where every classroom has not fewer than one exterior exit door at ground level, an automatic sprinkler system is not required in any area below the lowest level of exit discharge serving that area.

3. The Group E fire area has an occupant load of 300 or more.
4. In rooms or areas with special hazards such as laboratories, vocational shops and other such areas where hazardous materials in quantities not exceeding the maximum allowable quantity are used or stored.
5. Throughout any Group E structure greater than 3,600 square feet in area, which contains more than one fire area, and which is separated into two or more buildings by fire walls of less than 4-hour fire resistance rating without openings.
6. For public school state funded construction projects see Section 903.2.19.
7. For public school campuses, Kindergarten through 12th grade, see Section 903.2.20

SECTION 903.2.4 "GROUP F-1" SHALL BE AMENDED AS FOLLOWS:

Section 903.2.4 Group F-1. An automatic sprinkler system shall be provided throughout all buildings containing a Group F-1 occupancy where one of the following conditions exists:

1. A Group F-1 fire area exceeds 3,600 square feet.
2. A Group F-1 fire area is located more than three stories above grade plane.
3. The combined area of all Group F-1 fire areas on all floors, including any mezzanines, exceeds 3,600 square feet.

SECTION 903.2.7 "GROUP M" SHALL BE AMENDED AS FOLLOWS:

Section 903.2.7 Group M. An automatic sprinkler system shall be provided throughout buildings containing a Group M occupancy where one of the following conditions exists:

1. A Group M fire area exceeds 3,600 square feet.
2. A Group M fire area is located more than three stories above grade plane.
3. The combined area of all Group M fire areas on all floors, including any mezzanines, exceeds 3,600 square feet.
5. The structure exceeds 3,600 square feet, contains more than one fire area containing a Group M occupancy, and is separated into two or more buildings by fire walls of less than 4-hour fire resistance rating without openings.

SECTION 903.2.7.2 "GROUP M UPHOLSTERED FURNITURE OR MATTRESSES" SHALL BE AMENDED AS FOLLOWS:

Section 903.2.7.2 Group M Upholstered Furniture or Mattresses. An automatic sprinkler system shall be provided throughout a Group M fire area where the area used for the display and sale of upholstered furniture or mattresses exceeds 3,600 square feet.

SECTION 903.2.8.5 "MANUFACTURED HOMES" SHALL BE ADDED AS FOLLOWS:

Section 903.2.8.5 Manufactured Homes. *An automatic fire sprinkler system shall be required in all new manufactured homes and multi-family manufactured homes intended for use as a one-and two-family dwelling. The design and installation of such systems shall be in accordance with California Code of Regulations, Title 25, §4300.*

Exceptions:

1. *Manufactured homes located within an existing mobile home park complying with California Health and Safety Code, Division 13, Part 2.1 or 2.3.*
2. *Manufactured homes that do not exceed 1,200 square feet in size and serve as an accessory dwelling unit, as defined in Government Code Section 658502; when the existing primary residence on the property is not required to comply with California Residential Code Section R313.2.*
3. *Manufactured homes that do not exceed 320 square feet in size.*

SECTION 903.2.9 “GROUP S-1” SHALL BE AMENDED AS FOLLOWS:

Section 903.2.9 Group S-1. An automatic sprinkler system shall be provided throughout all buildings containing a Group S-1 occupancy where one of the following conditions exists:

1. A Group S-1 fire area exceeds 3,600 square feet.
2. A Group S-1 fire area is located more than three stories above grade plane.
3. The combined area of all Group S-1 fire areas on all floors, including any mezzanines, exceeds 3,600 square feet.
4. A Group S-1 fire area used for the storage of commercial motor vehicles where the fire area exceeds 3,600 square feet.

SECTION 903.2.10 “GROUP S-2” SHALL BE AMENDED AS FOLLOWS:

Section 903.2.10 Group S-2. An automatic sprinkler system shall be provided throughout buildings classified as parking garages where any of the following conditions exist:

1. Where the fire area of the enclosed parking garage, in accordance with Section 406.6 of the California Building Code, exceeds 3,600 square feet.
2. Where the enclosed parking garage, in accordance with Section 406.6 of the California Building Code, is located beneath other groups.

Exception: Enclosed parking garages located beneath Group R-3 occupancies.

3. Where the fire area of the open parking garage, in accordance with Section 406.5 of the California Building Code, exceeds 3,600 square feet.

SECTION 903.2.10.1 “COMMERCIAL PARKING GARAGES” SHALL BE AMENDED AS FOLLOWS:

Section 903.2.10.1 Commercial Parking Garages. An automatic sprinkler system shall be provided throughout buildings used for storage of commercial motor vehicles where the fire area exceeds 3,600 square feet.

SECTION 903.2.22 “GROUP B” SHALL BE ADDED AS FOLLOWS:

Section 903.2.22 Group B. *An automatic sprinkler system shall be provided throughout all buildings containing Group B occupancies where the fire area exceeds 3,600 square feet.*

SECTION 903.2.23 “GROUP F-2” SHALL BE ADDED AS FOLLOWS:

Section 903.2.23 Group F-2. *An automatic sprinkler system shall be provided throughout all buildings containing Group F-2 occupancies where the fire area exceeds 3,600 square feet.*

SECTION 903.6 “WHERE REQUIRED IN EXISTING BUILDINGS AND STRUCTURES” IS AMENDED AS FOLLOWS:

Section 903.6 Where Required In Existing Buildings and Structures. An automatic sprinkler system shall be provided in existing buildings and structures where required in Chapter 11 *and as follows:*

1. When there is a change in occupancy classification that results in an increased life safety or fire risk, as determined by the fire code official, and the structure exceeds 3,600 square feet, an automatic fire sprinkler system shall be installed throughout the building.
2. *In existing buildings 3,600 square feet or greater, other than one and two-family dwelling units, and agricultural buildings not under special use permit for commercial purposes, where the floor area of the building or structure is increased, such building or structure shall be made to conform to Section 903.2.*

Exception: *When the building increase is less than 500 square feet.*

3. *In existing buildings 3,600 square feet or less, other than one-and two-family dwelling units, and agricultural buildings not under special use permit for commercial purposes, where the floor area of the building or structure is increased to a total square footage over 3,600 square feet, such building or structure shall be made to conform to Section 903.2.*

Exception: *When the building increase is less than 500 square feet.*

SECTION 907.2. “WHERE REQUIRED – NEW BUILDINGS AND STRUCTURES” SHALL BE AMENDED AS FOLLOWS:

Section 907.2. Where Required – New Buildings and Structures. An approved fire alarm system installed in accordance with the provisions of this code and NFPA 72 shall be provided in new buildings and structures in accordance with Sections 907.2.1 through 907.2.30 and provide occupant notification in accordance with Section 907.5, unless other requirements are provided by another section of this code.

Not fewer than one manual fire alarm box shall be provided in an approved location to initiate a fire alarm signal for fire alarm systems employing automatic fire detectors or waterflow detection devices. Where other sections of this code allow elimination of fire alarm boxes due to sprinklers or automatic fire alarm systems, a single fire alarm box shall be installed at a location approved by the enforcing agency.

Exceptions:

1. The manual fire alarm box is not required for fire alarm control units systems dedicated to elevator recall control, supervisory service and fire sprinkler monitoring.
2. The manual fire alarm box is not required for Group R-2 occupancies unless required by the fire code official to provide a means for fire watch personnel to initiate an alarm during a sprinkler system, impairment event. Where provided, the manual fire alarm box shall not be located in an area that is open to the public.
3. The manual fire alarm box is not required to be installed when approved by the fire code official.
4. *A fire alarm system is not required in one and two-family dwellings, agricultural buildings, and other occupancies classified as Group U not under special use permit and/or not used for commercial purposes (e.g. retail sales, food service, and/or special events).*
5. *Buildings with a floor area less than 500 square feet may be exempt, as determined by the fire code official based on building construction material and features, location, occupancy type, and distance to exposures.*

SECTION 907.2.1.4 "GROUP A UNDER 3,600 SQUARE FEET" SHALL BE ADDED AS FOLLOWS:

Section 907.2.1.4 Group A Under 3,600 Square Feet. *An approved fire alarm system shall be installed in all group A buildings with a floor area less than 3,600 square feet.*

SECTION 907.2.2.3 "GROUP B UNDER 3,600 SQUARE FEET" SHALL BE ADDED AS FOLLOWS:

Section 907.2.2.3 Group B Under 3,600 Square Feet. *An approved fire alarm system shall be installed in all group B buildings with a floor area less than 3,600 square feet.*

SECTION 907.2.3.11 "GROUP E UNDER 3,600 SQUARE FEET" SHALL BE ADDED AS FOLLOWS:

Section 907.2.3.11 Group E Under 3,600 Square Feet. *An approved fire alarm system shall be installed in all group E buildings with a floor area less than 3,600 square feet.*

SECTION 907.2.4.1 "GROUP F UNDER 3,600 SQUARE FEET" SHALL BE ADDED AS FOLLOWS:

Section 907.2.4.1 Group F Under 3,600 Square Feet. *An approved fire alarm system shall be installed in all group F buildings with a floor area less than 3,600 square feet.*

SECTION 907.2.5.2 "GROUP H UNDER 3,600 SQUARE FEET" SHALL BE ADDED AS FOLLOWS:

Section 907.2.5.2 Group H Under 3,600 Square Feet. *An approved fire alarm system shall be installed in all group H buildings with a floor area less than 3,600 square feet.*

SECTION 907.2.6.6 “GROUP I UNDER 3,600 SQUARE FEET” SHALL BE ADDED AS FOLLOWS:

Section 907.2.6.6 Group I Under 3,600 Square Feet. *An approved fire alarm system shall be installed in all group I buildings with a floor area less than 3,600 square feet.*

SECTION 907.2.7.2 “GROUP M UNDER 3,600 SQUARE FEET” SHALL BE ADDED AS FOLLOWS:

Section 907.2.7.2 Group M Under 3,600 Square Feet. *An approved fire alarm system shall be installed in all group M buildings with a floor area less than 3,600 square feet.*

SECTION 907.2.8.4 “GROUP R-1 UNDER 3,600 SQUARE FEET” SHALL BE ADDED AS FOLLOWS:

Section 907.2.8.4 Group R-1 Under 3,600 Square Feet. *An approved fire alarm system shall be installed in all group R-1 buildings with a floor area less than 3,600 square feet.*

SECTION 907.2.9.4 “GROUP R-2, R-2.1, R-2.2 UNDER 3,600 SQUARE FEET” SHALL BE ADDED AS FOLLOWS:

Section 907.2.9.4 Group R-2, R-2.1, R-2.2 Under 3,600 Square Feet. *An approved fire alarm system shall be installed in all group R-2, R-2.1, R-2.2 buildings with a floor area less than 3,600 square feet.*

SECTION 907.2.10.1 “GROUP S UNDER 3,600 SQUARE FEET” SHALL BE ADDED AS FOLLOWS:

Section 907.2.10.1 Group S Under 3,600 Square Feet. *An approved fire alarm system shall be installed in all group S buildings with a floor area less than 3,600 square feet.*

907.2.30 “TYPE I HOOD INSTALLATIONS” SHALL BE ADDED AS FOLLOWS:

907.2.30 “Type I Hood Installations. *The requirement of installation, or replacement, of a Type I Hood System shall require a fire alarm/sprinkler monitoring system to be installed, or for the hood system to be connected to an existing fire alarm/sprinkler monitoring system for that building.*

907.6.5 “MONITORING” SHALL BE AMENDED AS FOLLOWS:

907.6.5 Monitoring. *Fire alarm systems required by this chapter or by the California Building Code shall be monitored by an approved, UL certified, Type A Full Service central, proprietary or remote station service, which gives audible and visual signals at a constantly attended location. All sprinklered buildings shall be monitored.*

Exceptions:

1. *One- and two-family dwellings (R-3 Occupancies and other occupancies classified as “U”).*

2. *Agricultural buildings not under special use permit and/or not used for commercial purposes (e.g., retails sales, food service, and/or special events).*

SECTION 907.6.2.1 “SECONDARY POWER SUPPLY” SHALL BE ADDED AS FOLLOWS:

SECTION 907.6.2.1 SECONDARY POWER SUPPLY. *Where required by the fire code official, in accordance with NFPA 72, the secondary power supply providing a minimum 24-hour power capacity under quiescent load (system operating in a non-alarm condition) shall be amended to a minimum 72-hour power capacity.*

Exception: *The existence of an emergency back-up power supply that meets or exceed the requirements of California Fire Code Chapter 12.*

SECTION 907.9 “WHERE REQUIRED IN EXISTING BUILDINGS” SHALL BE AMENDED AS FOLLOWS:

SECTION 907.9 Where Required. *An approved fire alarm system shall be provided in existing buildings and structures where required in Chapter 11 and in existing buildings with a floor area less than 3,600 square feet without an approved automatic sprinkler system, other than one- or two-family dwelling units, agricultural building not under special use permit for commercial purposes where a fire alarm detection system does not exist and the floor area of the building or structure is increased*

Exception: *When the building increase is less than 500 square feet.*

Chapter 12

SECTION 1203.1.3 “INSTALLATION” SHALL BE AMENDED AS FOLLOWS:

Section 1203.1.3 Installation. *Emergency power systems and standby power systems shall be installed in accordance with the California Building Code, the California Electrical Code, NFPA 110 and NFPA 111. All buildings, other than one- and two-family dwelling units, and agricultural buildings not used for commercial purposes, with standby power, shall have a shunt trip device that disconnects all power sources to the building, approved by the fire code official. Existing installations shall be maintained in accordance with the original approval.*

Chapter 33

SECTION 3311.3 “PREMISE IDENTIFICATION” SHALL BE ADDED AS FOLLOWS:

Section 3311.3 Premise Identification. *Prior to and during construction, an approved address sign shall be provided at each fire and emergency vehicle access road entry into the project.*

SECTION 3313.1 “WHEN REQUIRED” SHALL BE AMENDED AS FOLLOWS:

Section 3313.1 When Required. *An approved water supply for fire protection, either temporary or permanent, shall be installed and maintained in continuous operation as soon as combustible building materials arrive on site, the commencement of vertical combustible*

construction and on installation of a standpipe system in buildings under construction, in accordance with Sections 3313.2 through 3313.5.

Exception: The fire code official is authorized to reduce the fire-flow requirements for isolated buildings or a group of buildings in rural areas or small communities where the development of full fire-flow requirements is impractical.

Chapter 50

SECTION 5001.7 “LIABILITY FOR DAMAGES” SHALL BE ADDED AS FOLLOWS:

Section 5001.7 Liability for Damages. *Any damages or cost resulting from the negligence, violation of the law, careless handling, spill or discharge of any hazardous materials shall constitute debt against any such person, firm or corporation causing such spill or discharge. This debt is collectible by the Fire Chief, or his/her duly authorized representative, in the same manner as in the case of an obligation under contract, expressed or implied.*

Chapter 56

SECTION 5601.2 “PERMIT REQUIRED” SHALL BE AMENDED AS FOLLOWS:

Section 5601.2 Permit Required. Permits shall be required as set forth in Section 105.5 and regulated in accordance with this section. *Where fireworks permits are required, they shall be issued by the Fire Chief, or his/her duly authorized representative, and the El Dorado County Board of Supervisors.*

Chapter 57

SECTION 5704.2.9.6.1 “LOCATIONS WHERE ABOVE-GROUND TANKS ARE PROHIBITED” SHALL BE AMENDED AS FOLLOWS:

SECTION 5704.2.9.6.1 Locations Where Above-Ground Tanks are Prohibited. Storage of Class I and Class II flammable liquids in above-ground tanks outside of buildings is prohibited within the limits established by law as the limits of districts in which such storage is prohibited. *Storage of Class I and Class II flammable liquids in above-ground tanks outside of buildings is prohibited unless approved by the fire code official.*

SECTION 5706.2.4.4 “LOCATIONS WHERE ABOVE-GROUND TANKS ARE PROHIBITED” SHALL BE AMENDED AS FOLLOWS:

SECTION 5706.2.4.4 Locations Where Above-Ground Tanks are Prohibited. The storage of Class I and Class II liquids in above-ground tanks is prohibited within the limits established by law as the limits of districts in which such storage is prohibited. *Storage of Class I and Class II liquids in above-ground tanks is prohibited unless approved by the fire code official.*

Chapter 58

SECTION 5806.2 "LIMITATIONS" SHALL BE AMENDED AS FOLLOWS:

SECTION 5806.2 Limitations. Storage of flammable cryogenic fluids in stationary containers outside of buildings is prohibited within the limits established by law as the limits of districts in which such storage is prohibited. *Storage of flammable cryogenic fluids in stationary containers outside of buildings is prohibited unless approved by the fire code official.*

Chapter 61

SECTION 6104.2 "MAXIMUM CAPACITY WITHIN ESTABLISHED LIMITS" SHALL BE AMENDED AS FOLLOWS:

SECTION 6104.2 Maximum Capacity within Established Limits. Within the limits established by law restricting the storage of liquefied petroleum gas for the protection of heavily populated or congested areas, the aggregate capacity of any one installation shall not exceed a water capacity of 2,000 gallons. *The storage of liquefied petroleum gas in excess of an aggregate of 2,000-gallon water capacity when located at least one-half (1/2) mile from property zoned or designated for residential use and at least one-half (1/2) mile from existing residential development with a density greater than one (1) dwelling unit per acre and at least one-half (1/2) mile from any hotel or motel is allowed when approved by the fire code official, and a special/conditional use permit is issued by the County of El Dorado.*

Dispensing within established limits. Within the limits established by law restricting the dispensing of liquefied petroleum gas for the protection of heavily populated or congested areas, the aggregate capacity of any one installation shall not exceed a water capacity of 2,000 gallons. The dispensing of liquefied petroleum gas in excess of an aggregate of 2,000-gallon water capacity when located at least one-half (1/2) mile from property zoned or designated for residential use and at least one-half (1/2) mile from any hotel or motel is allowed when approved by the fire code official and a special/conditional use permit is issued by the County of El Dorado.

Chapter 80

SECTION 80, NFPA 1-22, CHAPTER 22 "AUTOMOTIVE WRECKING YARDS" IS ADOPTED, AMENDED SECTIONS AS FOLLOWS:

Revise Section 22.3 as follows:

22.3 Fire department access roads shall be in accordance with the California Fire Code, Section 503 and Appendix D.

Add new Section 22.10 as follows:

22.10 Stored vehicles, boats, recreational vehicles, parts, and equipment shall not be stored within 30 feet of adjacent property lines.

SECTION 80, NFPA, 13D-22 – “STANDARD FOR THE INSTALLATION OF SPRINKLER SYSTEMS IN ONE-AND TWO FAMILY DWELLINGS AND MANUFACTURED HOMES” IS AMENDED AS FOLLOWS: 903.3.1.3, 903.3.5.1.1

NFPA 13D, Amended Sections as follows:

Add new Section 4.6 as follows:

4.6 Residential fire sprinkler systems installed in all new one-and two-family dwellings shall utilize a “Passive Purge” system design unless otherwise approved by the fire code official.

Exception: *Manufactured home installed, tested and approved by the California Department of Housing and Community Development.*

Revise Section 5.1.1.2 as follows:

5.1.1.2 *A supply of at least one of each type and temperature sprinkler used within the premises shall be maintained on the property at an approved location. Spare sprinklers shall be kept in a mounted and accessible cabinet.*

Revise Section 7.6 as follows:

7.6 *A local audio/visual device activated upon water flow shall be provided on all fire sprinkler systems in homes at an approved location on the exterior of the dwelling.*

Revise Section 11.2.1.1 as follows:

11.2.1.1 *Where a fire department pumper connection is not provided, the system shall be hydrostatically tested at a minimum pressure of 150 pounds per square inch gauge for no less than a 30-minute duration without evidence of leakage. Such test shall be witnessed by the fire code official.*

Appendix B – Fire Flow Requirements for Buildings

TABLE B105.1(1) “REQUIRED FIRE FLOW FOR ONE- AND TWO-FAMILY DWELLINGS, GROUP R-3, AND R-4 BUILDINGS AND TOWNHOUSES” SHALL BE AMENDED AS FOLLOWS:

TABLE B105.1(1) REQUIRED FIRE FLOW FOR ONE- AND TWO-FAMILY DWELLINGS, GROUP R-3, AND R-4 BUILDINGS AND TOWNHOUSES

FIRE-FLOW CALCULATION AREA (square feet)	AUTOMATIC SPRINKLER SYSTEM (Design Standard)	MINIMUM FIRE-FLOW (gallons per minute)	FLOW DURATION (hours)
0 – 3,600	No automatic sprinkler system	1,000	1

3,601 and greater	No automatic sprinkler system	Value in Table B105.1(2)	Duration in Table B105.1(2) at the required fire-flow rate
MAJOR SUBDIVISIONS (5 PARCELS OR GREATER)			
0 – 3,600	Section 903.3.1.3 of the CA Fire Code or Section 313.3 of the CA Residential Code	1,000	1
3,601 and greater	Section 903.3.1.3 of the CA Fire Code or Section 313.3 of the CA Residential Code	1/2 value of Table B105.1(2) (min. 1000 GPM)	2
OTHER RESIDENTIAL DEVELOPMENT			
0 – 3,600	Section 903.3.1.3 of the CA Fire Code or Section 313.3 of the CA Residential Code	500	1
3,601 and greater	Section 903.3.1.3 of the CA Fire Code or Section 313.3 of the CA Residential Code	1/2 value of Table B105.1(2) (min. 750 GPM)	1

TABLE B105.2 “REQUIRED FIRE FLOW FOR BUILDINGS OTHER THAN ONE- AND TWO-FAMILY DWELLINGS, GROUP R-3, AND R-4 BUILDINGS AND TOWNHOUSES” SHALL BE AMENDED AS FOLLOWS:

TABLE B105.2 REQUIRED FIRE FLOW FOR BUILDINGS OTHER THAN ONE- AND TWO-FAMILY DWELLINGS, GROUP R-3, AND R-4 BUILDINGS AND TOWNHOUSES

AUTOMATIC SPRINKLER SYSTEM (Design Standard)	MINIMUM FIRE-FLOW (gallons per minute)	FLOW DURATION (hours)
No automatic sprinkler system	Value in Table B105.1(2)	Duration in Table B105.1(2)
Section 903.3.1.1 of the CA Fire Code	25% of the value in Table B105.1(2) ^b	Duration in Table B105.1(2) at the reduced flow rate

b. The reduced fire flow shall not be less than 1,500 gpm

Appendix D – Fire Apparatus Access Roads

SECTION D103.1 “ACCESS ROAD WIDTH WITH A HYDRANT” SHALL BE AMENDED AS FOLLOWS:

Section D103.1 Access Road Width with a Hydrant. Where a fire hydrant is located on a fire apparatus access road, the minimum road width shall be 26 feet (7925 mm), exclusive of shoulders (see Figure D103.1).

Exception: Driveways

SECTION D103.2 “GRADE” SHALL BE AMENDED AS FOLLOWS:

SECTION D103.2 Grade. Fire apparatus access roads *and driveways* shall not exceed 15.9% in grade unless approved by the fire code official or by the El Dorado County amended California Public Resource Code Title 14 / Design and Improvement Standards Manual.

SECTION D103.3 “TURNING RADIUS” SHALL BE AMENDED AS FOLLOWS:

SECTION D103.3 Turning Radius. The minimum turning radius shall be determined by the fire code official; *and shall not include curb and gutter.*

SECTION D103.5 “FIRE APPARATUS ACCESS ROAD GATES” SHALL BE AMENDED AS FOLLOWS:

SECTION D103.5 Fire Apparatus Access Road Gates. Gates securing the fire apparatus access roads shall comply with all of the following criteria:

1. Where a single gate is provided, the gate width shall be not less than 20 feet (6096 mm). Where a fire apparatus road consists of a divided roadway, the gate width shall be not less than 15 feet (3658 mm).
2. Gates shall be of the horizontal swing, horizontal slide, vertical lift or vertical pivot type.
3. Construction of gates shall be of materials that allow manual operation by one person.
4. Gate components shall be maintained in an operative condition at all times and replaced or repaired when defective.
5. Electric gates shall be equipped with a means of opening the gate by fire department personnel for emergency access. Emergency opening devices shall be approved by the fire code official.
6. Methods of locking shall be submitted for approval by the fire code official.
7. Electric gate operators, where provided, shall be listed in accordance with UL 325.
8. Gates intended for automatic operation shall be designed, constructed and installed to comply with the requirements of ASTM F2200.

SECTION D103.6.1 “ROADS 20 TO 29 FEET IN WIDTH” SHALL BE AMENDED AS FOLLOWS:

SECTION D103.6.1 Roads 20 to 29 feet in width. Fire lane signs as specified in Section D103.6 shall be posted on both side of fire apparatus access roads that are 20 to 29 feet wide (6096 to 8534.4 mm).

SECTION D103.6.2 “ROADS MORE THAN 29 FEET IN WIDTH” SHALL BE AMENDED AS FOLLOWS:

SECTION D103.6.2 Roads more than 29 feet in Width. Fire lane signs as specified in Section D103.6 shall be posted on one side of fire apparatus access roads more than 29 feet wide (8534.4 mm) and less than 36 feet wide (10972.8 mm).

SECTION D104.4 “CIRCUMFERENTIAL FIRE APPARATUS ACCESS ROADS” SHALL BE ADDED AS FOLLOWS:

SECTION D104.4 Circumferential Fire Apparatus Access Roads. *When required by the fire code official, a fire apparatus access road shall be constructed to encompass the entirety of a structure and shall provide a continuous means of emergency vehicle access.*

SECTION 4: CONFLICT

That Ordinance No. 2019-01 of the RFPD, and all other ordinances or parts of ordinances herewith are hereby repealed.

SECTION 5: SEVERABILITY

If any Ordinance, article, subsection or subdivision thereof, provision, sentence, clause or phrase of this code, or any application thereof, is for any reason held to be invalid by a court of competent jurisdiction, such decision shall not affect the remaining provisions of this code, which can be given effect without the invalid portions and, therefore, such invalid portions are declared to be severable. The RFPD hereby declares that it would have enacted this Ordinance and each of its articles, sections, subsections, or subdivisions thereof, provisions, sentences, clauses or phrases irrespective of the fact that one or more of them is declared invalid.

SECTION 6: EFFECTIVE DATE AND PUBLICATION

This Ordinance shall take effect thirty (30) days after its adoption. RFPD Board Secretary is directed to publish this ordinance in a newspaper of general circulation in the District. In lieu of publication of the full text of the ordinance, a summary of the ordinance may be published by the by the Board Secretary within fifteen (15) days after its passage and a certified copy shall be posted in the office of the RFPD pursuant to *Government Code Section 36933(c) (1)*.

The above Ordinance was introduced at a meeting of the Board of Directors of the RFPD on September 14, 2022, and it was then read for the first time. A public hearing was set for the Ordinance to be read for the second time on October 12, 2022 and approved by the following vote:

PASSED AND ADOPTED by the Board of Directors of the Rescue Fire Department this, _____ day of _____, 2022.

AYES:

NOES:

ABSENT:

ABSTAIN:

XXXX, Board President

ATTEST:

Aja Mercado, Board Secretary

SECTION 2: FINDINGS OF FACTS

In connection with the amendments enacted by Section 2 and 3 relating to the California Fire Code and its appendix, 2022 edition, the Rescue Fire Protection District (RFPD) makes the following findings pursuant to Health and Safety Code Section 17958.5, 17958.7 and 18941.5. The changes are reasonably necessary because of local climatic, topographical or geological conditions.

RFPD hereby adopts pursuant to Section 18941.5 of the California Health and Safety Code, the following findings of fact:

(a) Under this adopting ordinance, specific amendments have been established which are of a more restrictive nature than those adopted by the State of California (State Buildings Standards Code, State Housing & Community Development Codes) commonly referred to as Title 24 & Title 25 of the California Code of Regulations. These amendments to the California Fire Code 2022 edition, have been recognized by the RFPD to address the fire problems, concerns and future direction by which RFPD can establish and maintain an environment which will afford a level of fire and life safety to all who live and work within its boundary.

(b) The International Code Council has assumed responsibility for the International Fire Code and International Fire Code Standards. The International Code Council provided a means for participation by all code enforcement officials from throughout the country as well as industry representatives, consultants, and other private parties with an interest in the International Fire Code.

(c) The International Fire Code, being the 2021 edition thereof, published by the International Code Council is a nationally recognized compilation of proposed rules, regulations and standards of said Association.

(d) Said International Fire Code has been printed and published as a Code in book form within the meaning of Section 50022.1 of the Government Code of the State of California.

(e) Under the provisions of Section 18941.5 of the Health and Safety Code, local amendments are based on climatic, topographical and geological conditions. The findings of fact contained herein address each of these situations and present the local situation, which either singularly or in combination, caused the aforementioned amendments to be adopted.

2022 CFC FINDINGS

LOCAL CONDITIONS

A. These amendments are justified on the basis of a local climatic condition. RFPD is subject to precipitation, relative humidity, temperature extremes, and high velocity winds.

1. Precipitation & relative humidity

a. Conditions

Precipitation. Average annual precipitation ranges from approximately 25 to 32 inches per year. Approximately 88% of the average rainfall occurs during the months of November through April and 12% from May through October. This area has experienced major droughts in the last two decades: 1986 -1991, 1998 – 2003, 2007 - 2009, and 2011 - 2015. It is possible that more droughts will occur in the future based on the weather cycle pattern.

Relative Humidity. During the summer months (May through September), the daily humidity generally ranges around 20% and occasionally drops to the low teens.

2. Temperature

a. Conditions

Temperatures. During the summer months (May through September), the daily temperatures commonly exceed 90 degrees Fahrenheit, with temperatures having been recorded as high as 115 degrees.

3. Winds

a. Conditions

Winds. The summer prevailing winds are out of the south and southwest. However, north winds occur during the spring (April and May), the fall (September and October), and occasionally during the summer months (June, July and August). Velocities are generally in the range of five to fifteen miles per hour, gusting to 30 miles per hour during the summer months.

SUMMARY

These local climatic conditions affect the acceleration, intensity and size of fire in the community. Times of little or no rainfall and high temperatures create extremely hazardous conditions, particularly as they relate to residential roof fires and wildfire conflagrations. The climatic conditions are one of the greatest impacts to fire behavior and other major emergency events due to their uncontrollable nature.

2022 CFC FINDINGS

B. These amendments are justified on the basis of a local geologic and topographic conditions. RFPD is subject to varied terrain, slopes, increased vegetation, varied surface features, hazardous building operations, and terrain risk factors.

1. Geological location

a. Conditions

Geological Location. Rescue is located in the foothills of the Sierra at an altitude range of approximately 650 feet to 1,500 feet above sea level.

2. Size and population

a. Conditions

Size and Population. The RFPD encompasses approximately twenty to thirty (20-30) square miles and has a current population of approximately 6,500 residents.

3. Seismic Location

a. Conditions

Seismic Location. The nearest identified fault zone running through the District is the Bear Mountain Fault. This fault zone is split into several branches which transect the area between Folsom and Shingle Springs. The closest branch passes through the middle of the District along the western edge of Browns Ravine. The next nearest extension of this fault system is located immediately at the north end of the District, and extends from the southeast arm of Folsom Lake, north to the City of Auburn. No recent geologic activity has been observed along this fault. However, studies of the east branch of the fault zone, conducted by Woodward-Clyde Associates for the Auburn Dam, and by Tierra Engineering Consultants near Folsom Lake, indicate that the fault may be reactivating based on recent tectonic trends and should be considered potentially active.

4. Topography

a. Conditions

Topography. The topography of the District varies from level 0% slope to terrain with over a 40% slope. The valley floor is relatively flat with gentle slopes and consists of grassland and trees. The east and west sides of the valley floor increase to approximately 40% slopes and consist of trees, brush and grass-covered range land. The greatest degree of slope occurs in the northern end of the District and extends northeast from there. Hilly terrain throughout the area provides gullies or areas referred to as “chimneys” which accelerate the spread of fire.

2022 CFC FINDINGS

5. Roads and streets

a. Conditions

Roads and Streets. The District has seen an accelerated degree of urban and commercial development within the last 15 years. With this development comes the increase of vehicular traffic and congestion which can have a direct effect on the response time of emergency apparatus.

6. Building Clearances

a. Conditions

Building Clearances. As residential development continues to occur in the District, the clearance between homes has decreased which increases the ability of fire to spread from one home to another by both radiation and convection heat.

SUMMARY

The above geological and topographical conditions increase the magnitude, exposure, accessibility problems and fire hazards that the Department must handle. Fire following an earthquake has the potential of causing greater loss of life and damage to property than the earthquake itself.

Other variables may tend to increase the situation:

1. The damage that may occur to the water system, and;
2. The extent of isolation due to roadway damage, overpass collapse and debris blocking the roadway.

2022 CFC FINDINGS

<i>2022 CFC Code Section</i>	<i>Title</i>	<i>Adopted</i>	<i>Amended</i>	<i>Added</i>	<i>Deleted</i>	<i>Finding</i>
101.1	General		X			Administrative
102.6 - 102.12	Applicability	X				Administrative
104.1	Duties and Powers	X				Administrative
104.3 – 104.4	Duties and Powers	X				Administrative
104.6	Official Records	X				Administrative
104.8 – 104.8.2	Approved Materials	X				Administrative
104.9	Modifications	X				Administrative
104.11 – 104.12.3	Fire Investigation	X				Administrative
105.2.3	Time of Application	X				Administrative
105.3.2	Extensions	X				Administrative
105.5	Operational Permits					Administrative
105.5.55	Automobile Wrecking Yards			X		Administrative
105.6	Construction Permits		X			Administrative
105.6.25	Automobile Wrecking Yards			X		Administrative
105.6.9	Fuel Cell	X				Administrative
105.6.12	Hazardous Materials	X				Administrative
105.17	Plant Extraction	X				Administrative
105.18	Private Fire Hydrants	X				Administrative
105.19	Smoke Control	X				Administrative
105.6.21	Special Event Structure	X				Administrative
105.6.22	Spraying or Dipping	X				Administrative
105.6.23	Standpipe Systems	X				Administrative
105.6.24	Tents	X				Administrative
106.1 – 106.4	Construction Documents	X				Administrative
107.1	Fees	X				Administrative
107.5	Related Fees			X		Administrative
107.5.1	Cost Recovery			X		Administrative
107.6	Refunds	X				Administrative
107.7	Administrative Costs			X		Administrative
Section 108	Inspections	X				Administrative
Section 109	Maintenance	X				Administrative
111.5	Appeals			X		Administrative
112.4	Violation Penalties		X			Administrative
112.4.1	Abatement of Violations	X				Administrative
112.4.2	Citations			X		Administrative
Section 113	Stop Work Order					Administrative
113.4	Failure to Comply		X			Administrative

2022 CFC FINDINGS

2022 CFC Code Section	Title	Adopted	Amended	Added	Deleted	Finding
Section 114	Unsafe Structures	X				Administrative
202	Definitions		X			Administrative
Section 302	Definitions					Administrative
Section 303	Asphalt Kettles					A1, A2, A3, B1, B2. B3. B4, B5, B6
302.1	Definitions		X			Administrative
Section 304	Combustible Waste	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
Section 305	Ignition Sources	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
Section 306	Motion Picture	X				B1, B2. B3. B4, B5, B6
Section 307	Open Burning	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
307.4.4	Open Burning			X		A1, A2, A3, B1, B2. B3. B4, B5, B6
Section 308	Open Flames	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
Section 309	Powered Industrial Trucks	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
Section 310	Smoking	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
Section 311	Vacant Premises	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
Section 320	3D Printing	X				B1, B2. B3. B4, B5, B6
Section 321	Artificial Vegetation	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
403.2 – 403.2.4	Group A	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
403.6 – 403.6.1.4	Group F	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
403.9 – 403.9.3.4	Group R	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
503.2.1	Dimensions		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
503.2.5	Dead Ends		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
503.2.6	Bridges		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
503.3.1	No Parking – Fire Lanes			X		A1, A2, A3, B1, B2. B3. B4, B5, B6
503.3.2	No Parking – Fire Hydrants			X		A1, A2, A3, B1, B2. B3. B4, B5, B6
503.3.3	Fire Lane Width			X		A1, A2, A3, B1, B2. B3. B4, B5, B6
503.6	Security Gates		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
505.1	Address		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
507.5.1	Where Required – Fire Hydrants		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
509.3	Fire Control Rooms			X		B1, B2. B3. B4, B5, B6
807.5.2	Group E	X				B1, B2. B3. B4, B5, B6
903.2	Where Required – Fire Sprinklers		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
903.2.1.1	Group A		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
903.2.1.2	Group A-2		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
903.2.1.3	Group A-3		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
903.2.1.4	Group A-4		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
903.2.3	Group E		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
903.2.4	Group F-1		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
903.2.7	Group M		X			A1, A2, A3, B1, B2. B3. B4, B5, B6

2022 CFC FINDINGS

2022 CFC Code Section	Title	Adopted	Amended	Added	Deleted	Finding
903.2.7.2	Group M - Mattresses		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
903.2.8.5	Manufactured Homes			X		A1, A2, A3, B1, B2. B3. B4, B5, B6
903.2.9	Group S-1		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
903.2.10	Group S-2		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
903.2.10.1	Parking Garages		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
903.2.22	Group B			X		A1, A2, A3, B1, B2. B3. B4, B5, B6
903.2.23	Group F-2			X		A1, A2, A3, B1, B2. B3. B4, B5, B6
903.6	Where Required – Fire Sprinklers		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
907.2	Where Required – Fire Alarm Systems		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
907.2.1.4	Group A			X		A1, A2, A3, B1, B2. B3. B4, B5, B6
907.2.2.3	Group B			X		A1, A2, A3, B1, B2. B3. B4, B5, B6
907.2.3.11	Group E			X		A1, A2, A3, B1, B2. B3. B4, B5, B6
907.2.4.1	Group F-1			X		A1, A2, A3, B1, B2. B3. B4, B5, B6
907.2.5.2	Group H			X		A1, A2, A3, B1, B2. B3. B4, B5, B6
907.2.6.6	Group I			X		A1, A2, A3, B1, B2. B3. B4, B5, B6
907.2.7.2	Group M			X		A1, A2, A3, B1, B2. B3. B4, B5, B6
907.2.8.4	Group R-1			X		A1, A2, A3, B1, B2. B3. B4, B5, B6
907.2.9.4	Group R-2, R-2.1, R-2.2			X		A1, A2, A3, B1, B2. B3. B4, B5, B6
907.2.10.1	Group S			X		A1, A2, A3, B1, B2. B3. B4, B5, B6
907.2.30	Type I Hoods			X		B1, B2. B3. B4, B5, B6
907.6.5	Monitoring		X			B1, B2. B3. B4, B5, B6
907.6.2.1	Secondary Power Supply			X		A1, A2, A3, B1, B2. B3. B4, B5, B6
907.9	Where Required – Fire Alarm		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
Section 1101	General	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
Section 1102	Definitions	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
1103.2	Responder Communication	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
1103.5 – 1103.5.5	Sprinkler Systems	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
1103.7 – 1103.7.9.10	Fire Alarm Systems	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
1103.8 – 1103.8.5.3	Smoke Alarms	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
1103.9 – 1103.9.1	Carbon Monoxide Alarms	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
Section 1104	Egress	X				B1, B2. B3. B4, B5, B6
Section 1106	Outdoor Operations	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
1203.1.3	Installation		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
3311.3	Address		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
3313.1	When Required – Water Supply		X			A1, A2, A3, B1, B2. B3. B4, B5, B6

2022 CFC FINDINGS

<i>2022 CFC Code Section</i>	<i>Title</i>	<i>Adopted</i>	<i>Amended</i>	<i>Added</i>	<i>Deleted</i>	<i>Finding</i>
5001.7	Liability for Damages			X		Administrative
5601.2	Permit Required		X			Administrative
5704.2.9.6.1	Locations – Above Ground Tanks		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
5706.2.4.4	Locations – Above Ground Tanks		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
5806.2	Limitations		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
6104.2	Maximum Capacity		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
Chapter 80	Referenced Standards		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
Appendix B Table B105.1 (1)	Fire Flow - Residential		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
Appendix B Table B105.2	Fire Flow - Commercial		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
Appendix D	Fire Apparatus Access Roads	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
Appendix D, D103.1	Access Road Width		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
Appendix D, D103.2	Grade		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
Appendix D, D103.3	Turning Radius		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
Appendix D, D103.5	Gates		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
Appendix D, D103.6.1	Fire Lane Marking		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
Appendix D, D103.6.2	Fire Lane Marking		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
Appendix D, D104.4	Circumferential Fire Access		X			A1, A2, A3, B1, B2. B3. B4, B5, B6

SECTION 2: FINDINGS OF FACTS

In connection with the amendments enacted by Section 2 and 3 relating to the California Fire Code and its appendix, 2022 edition, the Rescue Fire Protection District (RFPD) makes the following findings pursuant to Health and Safety Code Section 17958.5, 17958.7 and 18941.5. The changes are reasonably necessary because of local climatic, topographical or geological conditions.

RFPD hereby adopts pursuant to Section 18941.5 of the California Health and Safety Code, the following findings of fact:

(a) Under this adopting ordinance, specific amendments have been established which are of a more restrictive nature than those adopted by the State of California (State Buildings Standards Code, State Housing & Community Development Codes) commonly referred to as Title 24 & Title 25 of the California Code of Regulations. These amendments to the California Fire Code 2022 edition, have been recognized by the RFPD to address the fire problems, concerns and future direction by which RFPD can establish and maintain an environment which will afford a level of fire and life safety to all who live and work within its boundary.

(b) The International Code Council has assumed responsibility for the International Fire Code and International Fire Code Standards. The International Code Council provided a means for participation by all code enforcement officials from throughout the country as well as industry representatives, consultants, and other private parties with an interest in the International Fire Code.

(c) The International Fire Code, being the 2021 edition thereof, published by the International Code Council is a nationally recognized compilation of proposed rules, regulations and standards of said Association.

(d) Said International Fire Code has been printed and published as a Code in book form within the meaning of Section 50022.1 of the Government Code of the State of California.

(e) Under the provisions of Section 18941.5 of the Health and Safety Code, local amendments are based on climatic, topographical and geological conditions. The findings of fact contained herein address each of these situations and present the local situation, which either singularly or in combination, caused the aforementioned amendments to be adopted.

2022 CFC FINDINGS

LOCAL CONDITIONS

A. These amendments are justified on the basis of a local climatic condition. RFPD is subject to precipitation, relative humidity, temperature extremes, and high velocity winds.

1. Precipitation & relative humidity

a. Conditions

Precipitation. Average annual precipitation ranges from approximately 25 to 32 inches per year. Approximately 88% of the average rainfall occurs during the months of November through April and 12% from May through October. This area has experienced major droughts in the last two decades: 1986 -1991, 1998 – 2003, 2007 - 2009, and 2011 - 2015. It is possible that more droughts will occur in the future based on the weather cycle pattern.

Relative Humidity. During the summer months (May through September), the daily humidity generally ranges around 20% and occasionally drops to the low teens.

2. Temperature

a. Conditions

Temperatures. During the summer months (May through September), the daily temperatures commonly exceed 90 degrees Fahrenheit, with temperatures having been recorded as high as 115 degrees.

3. Winds

a. Conditions

Winds. The summer prevailing winds are out of the south and southwest. However, north winds occur during the spring (April and May), the fall (September and October), and occasionally during the summer months (June, July and August). Velocities are generally in the range of five to fifteen miles per hour, gusting to 30 miles per hour during the summer months.

SUMMARY

These local climatic conditions affect the acceleration, intensity and size of fire in the community. Times of little or no rainfall and high temperatures create extremely hazardous conditions, particularly as they relate to residential roof fires and wildfire conflagrations. The climatic conditions are one of the greatest impacts to fire behavior and other major emergency events due to their uncontrollable nature.

2022 CFC FINDINGS

B. These amendments are justified on the basis of a local geologic and topographic conditions. RFPD is subject to varied terrain, slopes, increased vegetation, varied surface features, hazardous building operations, and terrain risk factors.

1. Geological location

a. Conditions

Geological Location. Rescue is located in the foothills of the Sierra at an altitude range of approximately 650 feet to 1,500 feet above sea level.

2. Size and population

a. Conditions

Size and Population. The RFPD encompasses approximately twenty to thirty (20-30) square miles and has a current population of approximately 6,500 residents.

3. Seismic Location

a. Conditions

Seismic Location. The nearest identified fault zone running through the District is the Bear Mountain Fault. This fault zone is split into several branches which transect the area between Folsom and Shingle Springs. The closest branch passes through the middle of the District along the western edge of Browns Ravine. The next nearest extension of this fault system is located immediately at the north end of the District, and extends from the southeast arm of Folsom Lake, north to the City of Auburn. No recent geologic activity has been observed along this fault. However, studies of the east branch of the fault zone, conducted by Woodward-Clyde Associates for the Auburn Dam, and by Tierra Engineering Consultants near Folsom Lake, indicate that the fault may be reactivating based on recent tectonic trends and should be considered potentially active.

4. Topography

a. Conditions

Topography. The topography of the District varies from level 0% slope to terrain with over a 40% slope. The valley floor is relatively flat with gentle slopes and consists of grassland and trees. The east and west sides of the valley floor increase to approximately 40% slopes and consist of trees, brush and grass-covered range land. The greatest degree of slope occurs in the northern end of the District and extends northeast from there. Hilly terrain throughout the area provides gullies or areas referred to as “chimneys” which accelerate the spread of fire.

2022 CFC FINDINGS

5. Roads and streets

a. Conditions

Roads and Streets. The District has seen an accelerated degree of urban and commercial development within the last 15 years. With this development comes the increase of vehicular traffic and congestion which can have a direct effect on the response time of emergency apparatus.

6. Building Clearances

a. Conditions

Building Clearances. As residential development continues to occur in the District, the clearance between homes has decreased which increases the ability of fire to spread from one home to another by both radiation and convection heat.

SUMMARY

The above geological and topographical conditions increase the magnitude, exposure, accessibility problems and fire hazards that the Department must handle. Fire following an earthquake has the potential of causing greater loss of life and damage to property than the earthquake itself.

Other variables may tend to increase the situation:

1. The damage that may occur to the water system, and;
2. The extent of isolation due to roadway damage, overpass collapse and debris blocking the roadway.

2022 CFC FINDINGS

<i>2022 CFC Code Section</i>	<i>Title</i>	<i>Adopted</i>	<i>Amended</i>	<i>Added</i>	<i>Deleted</i>	<i>Finding</i>
101.1	General		X			Administrative
102.6 - 102.12	Applicability	X				Administrative
104.1	Duties and Powers	X				Administrative
104.3 – 104.4	Duties and Powers	X				Administrative
104.6	Official Records	X				Administrative
104.8 – 104.8.2	Approved Materials	X				Administrative
104.9	Modifications	X				Administrative
104.11 – 104.12.3	Fire Investigation	X				Administrative
105.2.3	Time of Application	X				Administrative
105.3.2	Extensions	X				Administrative
105.5	Operational Permits					Administrative
105.5.55	Automobile Wrecking Yards			X		Administrative
105.6	Construction Permits		X			Administrative
105.6.25	Automobile Wrecking Yards			X		Administrative
105.6.9	Fuel Cell	X				Administrative
105.6.12	Hazardous Materials	X				Administrative
105.17	Plant Extraction	X				Administrative
105.18	Private Fire Hydrants	X				Administrative
105.19	Smoke Control	X				Administrative
105.6.21	Special Event Structure	X				Administrative
105.6.22	Spraying or Dipping	X				Administrative
105.6.23	Standpipe Systems	X				Administrative
105.6.24	Tents	X				Administrative
106.1 – 106.4	Construction Documents	X				Administrative
107.1	Fees	X				Administrative
107.5	Related Fees			X		Administrative
107.5.1	Cost Recovery			X		Administrative
107.6	Refunds	X				Administrative
107.7	Administrative Costs			X		Administrative
Section 108	Inspections	X				Administrative
Section 109	Maintenance	X				Administrative
111.5	Appeals			X		Administrative
112.4	Violation Penalties		X			Administrative
112.4.1	Abatement of Violations	X				Administrative
112.4.2	Citations			X		Administrative
Section 113	Stop Work Order					Administrative
113.4	Failure to Comply		X			Administrative

2022 CFC FINDINGS

2022 CFC Code Section	Title	Adopted	Amended	Added	Deleted	Finding
Section 114	Unsafe Structures	X				Administrative
202	Definitions		X			Administrative
Section 302	Definitions					Administrative
Section 303	Asphalt Kettles					A1, A2, A3, B1, B2. B3. B4, B5, B6
302.1	Definitions		X			Administrative
Section 304	Combustible Waste	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
Section 305	Ignition Sources	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
Section 306	Motion Picture	X				B1, B2. B3. B4, B5, B6
Section 307	Open Burning	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
307.4.4	Open Burning			X		A1, A2, A3, B1, B2. B3. B4, B5, B6
Section 308	Open Flames	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
Section 309	Powered Industrial Trucks	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
Section 310	Smoking	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
Section 311	Vacant Premises	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
Section 320	3D Printing	X				B1, B2. B3. B4, B5, B6
Section 321	Artificial Vegetation	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
403.2 – 403.2.4	Group A	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
403.6 – 403.6.1.4	Group F	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
403.9 – 403.9.3.4	Group R	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
503.2.1	Dimensions		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
503.2.5	Dead Ends		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
503.2.6	Bridges		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
503.3.1	No Parking – Fire Lanes			X		A1, A2, A3, B1, B2. B3. B4, B5, B6
503.3.2	No Parking – Fire Hydrants			X		A1, A2, A3, B1, B2. B3. B4, B5, B6
503.3.3	Fire Lane Width			X		A1, A2, A3, B1, B2. B3. B4, B5, B6
503.6	Security Gates		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
505.1	Address		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
507.5.1	Where Required – Fire Hydrants		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
509.3	Fire Control Rooms			X		B1, B2. B3. B4, B5, B6
807.5.2	Group E	X				B1, B2. B3. B4, B5, B6
903.2	Where Required – Fire Sprinklers		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
903.2.1.1	Group A		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
903.2.1.2	Group A-2		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
903.2.1.3	Group A-3		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
903.2.1.4	Group A-4		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
903.2.3	Group E		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
903.2.4	Group F-1		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
903.2.7	Group M		X			A1, A2, A3, B1, B2. B3. B4, B5, B6

2022 CFC FINDINGS

2022 CFC Code Section	Title	Adopted	Amended	Added	Deleted	Finding
903.2.7.2	Group M - Mattresses		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
903.2.8.5	Manufactured Homes			X		A1, A2, A3, B1, B2. B3. B4, B5, B6
903.2.9	Group S-1		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
903.2.10	Group S-2		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
903.2.10.1	Parking Garages		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
903.2.22	Group B			X		A1, A2, A3, B1, B2. B3. B4, B5, B6
903.2.23	Group F-2			X		A1, A2, A3, B1, B2. B3. B4, B5, B6
903.6	Where Required – Fire Sprinklers		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
907.2	Where Required – Fire Alarm Systems		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
907.2.1.4	Group A			X		A1, A2, A3, B1, B2. B3. B4, B5, B6
907.2.2.3	Group B			X		A1, A2, A3, B1, B2. B3. B4, B5, B6
907.2.3.11	Group E			X		A1, A2, A3, B1, B2. B3. B4, B5, B6
907.2.4.1	Group F-1			X		A1, A2, A3, B1, B2. B3. B4, B5, B6
907.2.5.2	Group H			X		A1, A2, A3, B1, B2. B3. B4, B5, B6
907.2.6.6	Group I			X		A1, A2, A3, B1, B2. B3. B4, B5, B6
907.2.7.2	Group M			X		A1, A2, A3, B1, B2. B3. B4, B5, B6
907.2.8.4	Group R-1			X		A1, A2, A3, B1, B2. B3. B4, B5, B6
907.2.9.4	Group R-2, R-2.1, R-2.2			X		A1, A2, A3, B1, B2. B3. B4, B5, B6
907.2.10.1	Group S			X		A1, A2, A3, B1, B2. B3. B4, B5, B6
907.2.30	Type I Hoods			X		B1, B2. B3. B4, B5, B6
907.6.5	Monitoring		X			B1, B2. B3. B4, B5, B6
907.6.2.1	Secondary Power Supply			X		A1, A2, A3, B1, B2. B3. B4, B5, B6
907.9	Where Required – Fire Alarm		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
Section 1101	General	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
Section 1102	Definitions	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
1103.2	Responder Communication	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
1103.5 – 1103.5.5	Sprinkler Systems	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
1103.7 – 1103.7.9.10	Fire Alarm Systems	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
1103.8 – 1103.8.5.3	Smoke Alarms	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
1103.9 – 1103.9.1	Carbon Monoxide Alarms	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
Section 1104	Egress	X				B1, B2. B3. B4, B5, B6
Section 1106	Outdoor Operations	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
1203.1.3	Installation		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
3311.3	Address		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
3313.1	When Required – Water Supply		X			A1, A2, A3, B1, B2. B3. B4, B5, B6

2022 CFC FINDINGS

<i>2022 CFC Code Section</i>	<i>Title</i>	<i>Adopted</i>	<i>Amended</i>	<i>Added</i>	<i>Deleted</i>	<i>Finding</i>
5001.7	Liability for Damages			X		Administrative
5601.2	Permit Required		X			Administrative
5704.2.9.6.1	Locations – Above Ground Tanks		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
5706.2.4.4	Locations – Above Ground Tanks		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
5806.2	Limitations		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
6104.2	Maximum Capacity		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
Chapter 80	Referenced Standards		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
Appendix B Table B105.1 (1)	Fire Flow - Residential		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
Appendix B Table B105.2	Fire Flow - Commercial		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
Appendix D	Fire Apparatus Access Roads	X				A1, A2, A3, B1, B2. B3. B4, B5, B6
Appendix D, D103.1	Access Road Width		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
Appendix D, D103.2	Grade		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
Appendix D, D103.3	Turning Radius		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
Appendix D, D103.5	Gates		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
Appendix D, D103.6.1	Fire Lane Marking		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
Appendix D, D103.6.2	Fire Lane Marking		X			A1, A2, A3, B1, B2. B3. B4, B5, B6
Appendix D, D104.4	Circumferential Fire Access		X			A1, A2, A3, B1, B2. B3. B4, B5, B6